



HAL
open science

Corrosion in CO₂ Post-Combustion Capture with Alkanolamines – A Review

Jean Kittel, S Gonzalez

► **To cite this version:**

Jean Kittel, S Gonzalez. Corrosion in CO₂ Post-Combustion Capture with Alkanolamines – A Review. Oil & Gas Science and Technology - Revue d'IFP Energies nouvelles, 2014, 69 (5), pp.915 - 929. 10.2516/ogst/2013161 . hal-01085365

HAL Id: hal-01085365

<https://ifp.hal.science/hal-01085365>

Submitted on 21 Nov 2014

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers.

L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

Corrosion in CO₂ Post-Combustion Capture with Alkanolamines – A Review

J. Kittel* and S. Gonzalez

IFP Energies nouvelles, Rond-point de l'échangeur de Solaize, BP 3, 69360 Solaize - France
e-mail: jean.kittel@ifpen.fr

* Corresponding author

Résumé — Corrosion dans les procédés utilisant des alcanolamines pour le captage du CO₂ en post-combustion — Les procédés de captage et de stockage du CO₂ occupent une place importante dans les stratégies visant à limiter les émissions industrielles de gaz à effet de serre. Les procédés de captage en post-combustion par solvant chimique de type alcanolamine sont bien adaptés au traitement d'émissions ponctuelles massives issues de combustibles fossiles, rencontrées notamment dans les centrales thermiques au charbon et au gaz, ou les industries sidérurgiques ou de production de ciment. La technologie utilisant le principe d'absorption – désorption par les alcanolamines est une des voies les plus matures à ce jour : elle est en effet déjà mise en œuvre, par exemple pour la désacidification du gaz naturel, bien qu'à une échelle sensiblement plus petite. L'opération de telles unités pour le traitement des fumées de combustion présente toutefois de nombreux challenges, parmi lesquels la corrosion des équipements tient une place importante. Le but de cet article est de présenter une revue des connaissances sur cet aspect particulier. Dans une première partie, l'expérience issue de plusieurs décennies d'utilisation de procédés aux alcanolamines dans le domaine de la production d'huile et de gaz est présentée. Dans une seconde partie, les risques spécifiques associés aux particularités des procédés de captage du CO₂ en post-combustion sont identifiés et discutés. Différentes stratégies de maîtrise de la corrosion sont décrites, et certains axes prioritaires en matière de recherche et développement sont proposés. Enfin, certaines difficultés en vue du transport du CO₂ issu du captage puis de son injection à fin de stockage géologique sont mises en avant, avec des recommandations strictes sur les teneurs maximales en impuretés pour disposer en toute sûreté du CO₂ issu de ce procédé.



Abstract — Corrosion in CO₂ Post-Combustion Capture with Alkanolamines – A Review — CO₂ capture and storage plays an important part in industrial strategies for the mitigation of greenhouse gas emissions. CO₂ post-combustion capture with alkanolamines is well adapted for the treatment of large industrial point sources using combustion of fossil fuels for power generation, like coal or gas fired power plants, or the steel and cement industries. It is also one of the most mature technologies to date, since similar applications are already found in other types of industries like acid gas separation, although not at the same scale. Operation of alkanolamine units for CO₂ capture in combustion fumes presents several challenges, among which corrosion control plays a great part. It is the aim of this paper to present a review of current knowledge on this specific aspect. In a first part, lessons learnt from several decades of use of alkanolamines for natural gas separation in the oil and gas industry are discussed. Then, the specificities of CO₂ post-combustion capture are presented, and

their consequences on corrosion risks are discussed. Corrosion mitigation strategies, and research and development efforts to find new and more efficient solvents are also highlighted. In a last part, concerns about CO₂ transport and geological storage are discussed, with recommendations on CO₂ quality and concentration of impurities.

INTRODUCTION

CO₂ capture roughly consists in separating different gases initially mixed in the combustion fumes. The main goal is to extract CO₂ before it is released in the atmosphere.

The most widely used process uses alkanolamine-based chemical solvents capable of reacting preferentially with CO₂. It is based on reversible chemical reactions between CO₂ and the aqueous amine, leading to the formation of bicarbonate and protonated amine (Reaction 1) and/or to the formation of amine carbamate (Reaction 2) [1].



In these reactions, R₁, R₂ and R₃ represent alkyl groups or a hydrogen atom.

While the mechanism of Reaction 1 may occur for all types of amine, it proceeds with relatively slow kinetics since it is limited by dissociation of carbonic acid into bicarbonate. It is thus not well adapted to CO₂ post-combustion capture which requires fast reactions.

On the contrary, Reaction 2 is much faster. However, since it leads to the formation of amine carbamate, it is only possible with primary or secondary amines which have hydrogen bond to the nitrogen. Therefore, tertiary amines are usually discarded for CO₂ capture applications, unless an activator is used to increase the reaction rates.

The industrial process of CO₂ capture with alkanolamines is described in Figure 1. It is based on the fact that chemical equilibria of Reaction 1 and Reaction 2 are shifted to the left at high temperature. This property is put into advantage in the industrial process, which consists of successive absorption – desorption in a loop system.

The flue gas which enters in the treatment plant at the bottom of the absorber is typically composed of nitrogen, with 10 to 20% of CO₂ and 5 to 10% O₂, with contaminants such as SO_x and NO_x at trace levels. The gas pressure is typically between 1 and 2 bar. Lean amine is introduced at the top of the column, and chemical reaction between the amine and CO₂ takes place.

At the liquid outlet at the bottom of the absorber, the solvent is enriched in acid gas: one speaks of rich amine. At the top of the absorber, the flue gas has been stripped of its CO₂.

The rich amine is then pre-heated to 90-110°C by a heat exchanger then fed into the top of a regeneration column (stripper). In this part of the unit, the solvent is raised to higher temperature by steam, typically between 120-130°C, which releases the dissolved CO₂. At the liquid outlet of the regenerator, the solvent is hot and contains less acid gas: one speaks of lean amine. The solvent is then cooled by the heat exchanger and sent back to the top of the absorber to start a new cycle. Pure CO₂ is collected at the top of the regenerator. When CO₂ is collected for geological sequestration, it has to be compressed to more than 100 bar for transportation. This compression step also represents an important penalty in terms of energy consumption.

This process using amines for acid gas separation has long been used for natural gas treatment, and it is well known that corrosion represents a major operational issue. A recent evaluation of cost of corrosion in gas sweetening plants concluded that 25% of the maintenance budget was committed to corrosion control [3]. It was also found that approximately half of the maintenance work orders were due to corrosion.

It is thus important to pay great attention to corrosion in the research and development work in progress for CO₂ capture with amines.

The present paper aims at presenting the current knowledge on this topic.

In the first section, experience from several decades in natural gas sweetening is presented. The main types of corrosion are described, and the impact of operational parameters on corrosion is discussed. Corrosion risks associated with the main equipments of the gas separation plant are then discussed individually, with a thorough analysis of industrial corrosion failures reported in the literature.

The second section deals with more recent work on amine process for CO₂ post-combustion capture. Mono-EthanolAmine (MEA) represents the benchmark solvent, and a detailed analysis of laboratory and pilot plant data obtained with this amine is proposed. A short paragraph is also dedicated to work in progress for the development of new solvents, aimed at being more efficient, less costly, and sometimes less corrosive than MEA.




Figure 1
Simplified diagram of a MEA CO₂ capture unit [2].

Finally, a brief look at corrosion issues in the CO₂ leaving the capture plant for transport and storage concludes the paper.

1 EXPERIENCE FROM NATURAL GAS SWEETENING

Using amines for the removal of acid gases is not a new process. It has been used for natural gas treatment or in refineries for several decades, and corrosion has always been considered as one of the major operational problems [4-11]. In the eighties, several industrial failures in gas treating plants were reported, the most important one causing the death of 17 employees [12-14]. Since then, lots of efforts were done to improve the understanding of corrosion processes in amine units. An extensive literature survey is proposed in the next paragraphs.

In such complex units, numerous pieces of equipment are exposed to equally numerous types of corrosion.

An interesting classification of the types of corrosion occurring in gas treatment plants was proposed by Nielsen [15], who identifies:

- wet acid gas corrosion,
- amine solution corrosion.

1.1 Acid Gas Corrosion

Wet acid gas corrosion is encountered in all parts of the unit in contact with an aqueous phase with a high

concentration of dissolved acid gases CO₂, H₂S, as well as NH₃ and HCN for refinery units. This type of corrosion is found primarily in zones where the gaseous phases have high concentrations of acid gases and where water may condense, mainly at the bottom of the absorber and the top of the regenerator [15, 16].

For gas containing mostly CO₂, parts of the installation made from carbon steel may suffer fast uniform corrosion, up to several mm/year. In the presence of H₂S, this uniform corrosion is generally delayed by the formation of a protective iron sulfide layer. A minimum H₂S/CO₂ ratio of 1/20 is often considered as sufficient to avoid risks of uniform CO₂ corrosion [17-19]. In the presence of H₂S however, specific cracking phenomena may also be encountered (hydrogen embrittlement, hydrogen induced cracking HIC, sulfide stress cracking SSC, etc.). In the presence of HCN and/or NH₃, the risks of cracking are also increased [16].

1.2 Corrosion by Amine Solution

1.2.1 Mechanisms and Influent Parameters

The second type of corrosive media found in acid gas removal units consists of amine solution. Generally, amines are not intrinsically corrosive, since they associate both high pH and low conductivity. They may nevertheless become corrosive when they absorb CO₂ or H₂S. Furthermore, since the treatment units operate in

semi-closed circuit, the solvent may become enriched with possibly corrosive degradation products [15, 18, 19].

No consensus has yet been reached concerning the mechanisms of corrosion by amine solutions. The models proposed vary depending on the type of amine (in particular, primary, secondary and tertiary), the H_2S/CO_2 ratio in the gas to be treated, the possible presence of oxygen either as contaminant in the circuit or as component of the input gas (*e.g.* CO_2 capture in fumes) [8, 10, 18, 20-23].

One may nevertheless identify some systematic trends governing the corrosivity of acid gas chemical solvents.

Acid gas loading (α) and temperature are usually considered as the most important factors. The acid gas loading is defined as the quantity of acid gas absorbed by a defined quantity of solvent and is often expressed in moles of acid gas per mole of amine. Increasing the acid gas loading increases the corrosivity of amine solutions [18, 19, 24, 25].

Temperature generally has an extremely important effect on corrosion phenomena since most electrochemical reactions involved are thermally activated. It is common practice in industry to consider that the corrosion rate is doubled when the operating temperature increases by 10 K to 20 K. For gas treatment units, the effect of temperature is relatively difficult to assess on an individual basis. Temperatures vary widely in the installation, with extreme values ranging from 40°C in the absorber up to 130°C in the reboiler. However, these temperature variations have a significant effect on the chemistry of the solution, in particular the acid gas loading. Taking into account both the loading and the temperature, it is usually considered that the main corrosion risks are encountered in areas with high loading and high temperatures [26]. These conditions are generally found in the rich amine line after the heat exchanger and up to the regenerator input.

The type of amine is also an important factor. Usually, primary amines (*e.g.* MEA) are the most corrosive, secondary amines (*e.g.* DiEthanolAmine, DEA) slightly less and tertiary amines (*e.g.* Methyl DiEthanolAmine, MDEA) exhibit the lowest risks of corrosion [18, 19, 25, 27-30]. Amine concentration also has an influence on corrosion. Excessively high amine concentrations should generally be avoided. Nevertheless, the results obtained from the few laboratory studies conducted on the effect of amine concentration on corrosivity vary widely, between a marked effect [18, 25] and a moderate or null effect [31, 32].

The concentration in degradation products and contaminants can significantly influence corrosion reactions. A distinction must be made between basic and acidic degradation products. Basic amine degradation

products mainly result from chain reactions between amine and CO_2 , for example the following compounds: HEOD (3-(2-hydroxyethyl)-2-oxazolidone), BHEP (N,N'-bis(2-hydroxyethyl)piperazine), THEED (N,N,N'-tris(2-hydroxyethyl)ethylenediamine). The studies on corrosion by these degradation products date back a number of years, the general conclusion being an absence of specific corrosivity [27, 28]. Most acidic degradation products result from reactions with oxygen. The main products include salts of oxalic, glycolic, formic and acetic acids, which are stronger than carbonic acid. As a result these salts are not thermally regenerated in the process, hence their name: Heat Stable Salts (HSS). The effect of these products on corrosion has been well documented through laboratory tests; they increase corrosion of carbon steel [33-35].

Finally, the solvent flow rate and conditions favourable to turbulence (gas flash, gas injection zones, etc.) may cause risks of erosion-corrosion. This type of corrosion is specific to carbon steels, since stainless steel grades are far more resistant. This type of corrosion is probably aggravated when the content of degradation products becomes too high: some of these products have a chelating effect on iron and may favour more efficient and faster dissolution of the protective deposits exposed to erosion [16, 17, 24, 36].

1.3 Equipments Concerned by Corrosion

This section describes the specific corrosion risks for the main equipment in gas treatment units. A summary is proposed in Table 1.

1.3.1 Absorber

The absorber may suffer several types of corrosion.

Among the parameters which affect corrosion, temperature and acid gas loading may vary on a wide range in the absorber. Temperature might typically evolve between ambient and 80°C, due to the exothermicity of absorption reactions. Acid gas loading may vary from lean (*i.e.* typically below $0.1 \text{ mol}_{CO_2}/\text{mol}_{\text{amine}}$) at the top of the absorber to rich (*i.e.* typically above $0.4 \text{ mol}_{CO_2}/\text{mol}_{\text{amine}}$) at the bottom. Therefore, the highest risks of corrosion by amine solution are found in the hot rich section at the bottom of the absorber. Erosion – corrosion represents an aggravating factor. In particular, the high flow rate at gas inlet may lead to turbulence and impingement of solution against the walls, creating conditions favourable to this type of corrosion. The same phenomenon is observed on the plates and in case of excessive flow rates.

TABLE 1
Summary of feedback on corrosion in amine units (CS = Carbon Steel)

Material and type of corrosion	Causes	References
Absorber		
CS – Cracking and mechanical failure	Hydrogen embrittlement or ASCC arising from non PWHT welds	[12, 14, 40, 42, 43]
CS – Uniform corrosion at bottom of absorber	Galvanic coupling with copper deposits from the corrosion inhibitor	[44]
CS – Erosion-corrosion at bottom of absorber	Turbulence at the raw gas inlet	[19, 45]
AISI 410 – Uniform corrosion of the plates	Higher corrosivity of sweet services units in high temperature and high loading zones	[26, 46]
Rich amine lines		
CS – Stress corrosion (ASCC)	No PWHT	[12, 14, 40, 42, 43]
CS – Erosion-corrosion	Excessive flow rates and acid gas flash	[19, 26, 45, 46]
CS – Localised corrosion with perforation	Large quantities of oxygen in the raw gas	[47]
Exchanger		
CS – Amine Stress Corrosion Cracking (ASCC)	No PWHT	[12, 14, 40, 42, 43]
CS – Erosion-corrosion	High temperatures and turbulence	[26, 46]
CS – Erosion-corrosion and pitting	Turbulence and acid gas flash from too high lean loading	[19, 40, 45]
316L and 254SMO – Failure of the exchanger trays	Possible case of stress corrosion	[26, 46]
Regenerator		
CS – Amine Stress Corrosion Cracking (ASCC)	No PWHT	[40]
CS – Erosion-corrosion of the internal parts	High corrosivity of the rich amine	[19, 26, 45, 46]
CS – Serious uniform corrosion	High HSS contents – Acid water condensation zones	[44, 48]
AISI 410 – Uniform corrosion of the trays	Corrosive conditions specific to sweet units, due to high loading and high temperatures	[26, 46]
AISI 304L – Uniform corrosion of internal parts and shells	Specific case of a DiGlycolAmine (DGA) unit	[49]
Reboiler		
CS – Uniform corrosion and erosion-corrosion	Turbulence, high concentration of degradation products	[26, 46, 50]
Lean amine lines		
CS – Amine Stress Corrosion Cracking (ASCC)	No PWHT	[12-14, 42]
CS – Erosion-corrosion	Too high lean loading	[40]
CS – Erosion-corrosion	Significant amine degradation due to the presence of oxygen in the raw gas	[41]

Wet acid gas corrosion may also develop at the bottom of the absorber and on the first plates, if the walls are not wetted sufficiently by the solvent: in this case, water may condense and become loaded with acid gases. Sour service units are prone to risks of hydrogen embrittlement.

For H₂S treatment units, specific risks of Amine Stress Corrosion Cracking (ASCC) are also possible, especially in the lower part of the absorber where the loading is highest. Post Weld Heat Treatment (PWHT) is then essential to reduce these risks [17].

1.3.2 Rich Amine Lines

Corrosion risks are especially high in this section where the amine is loaded with acid gas. Depending on the location before or after the heat exchanger, the temperature varies between 60°C to 110°C. Corrosion-erosion is the most frequent risk encountered with carbon steel lines subjected to high flow rate or flow disturbance. In particular, up to the flash drum, the solvent is pressurised and highly loaded with acid gas, and there is a high risk of degassing, which may aggravate the turbulence effects. Similarly, between the rich/lean amine exchanger and the regenerator, the risks of degassing remain high and are combined with a higher solvent temperature.

In the rich amine lines, it is commonly admitted that the solvent flow rate should not exceed 1.8 m/s [17].

1.3.3 Rich/Lean Amine Exchanger

This equipment is exposed to a wide range of highly specific corrosion risks.

On the rich amine side, the risks of erosion-corrosion mentioned in the previous paragraph still remain, especially if the rich amine inlet has been badly designed [4, 15].

When stainless steel plate exchangers are used, the main risks are stress corrosion cracking (especially at welds or in case of repairs) and crevice corrosion.

Sour service units are prone to risks of hydrogen embrittlement on the rich amine side of the exchanger, if it is made of carbon steel.

1.3.4 Regenerator and Acid Gas Outlet (Condenser, Reflux Drum)

The solvent at the top of the regenerator is still rich and already at high temperature. The intrinsic corrosivity is therefore very high and there is a serious risk of erosion-corrosion in case of turbulence. If there is no significant turbulence in the medium, extensive uniform corrosion of carbon steel is frequently observed. For this type of corrosion, it would also appear that the risks are greater in sweet service units (only CO₂), where fast uniform corrosion has been observed [26, 37, 38].

Wet acid gas corrosion is another major risk, especially at the top of the regenerator and in the acid gas outlet lines. The condenser is also highly sensitive. Experience has shown that keeping the gas flow rates above 8 m/s limits these risks considerably by preventing accumulation of condensates [26].

For sour service units, hydrogen embrittlement may occur at the top of the regenerator and in the acid gas outlet lines, in case of inappropriate choice of metal (non sour service carbon steel) or heat treatment (failure to carry out PWHT) [17].

1.3.5 Reboiler

Due to the high temperatures, the reboiler is relatively sensitive to corrosion and fouling [39]. The risks are elevated by solutions containing high concentrations of degradation products. If the regenerator fails to operate correctly (insufficient stripping), solvent still loaded with acid gas may be brought up to the reboiler, significantly increasing the risk of corrosion. Excessive temperatures also represent a recognised risk factor.

1.3.6 Lean Amine Lines

An extensive survey launched following the explosion of an absorber in 1984 detected cases of amine stress corrosion cracking in the lean amine lines, due mainly to failure to carry out PWHT [13, 14].

A case of erosion-corrosion has been reported for a MDEA unit in Indonesia [40], possibly due to an excessive lean loading ($\alpha > 0.02 \text{ mol}_{\text{CO}_2}/\text{mol}_{\text{amine}}$).

Another case is reported for a MDEA unit, where very severe corrosion of the lean amine parts developed just a few months after starting the unit [41]. This case would seem to have been caused by very fast degradation of MDEA to form bicine, due to the presence of oxygen in the gas to be treated, at a concentration of 90-100 ppmv.

1.4 From Natural Gas Sweetening to CO₂ Capture

If both natural gas sweetening and CO₂ capture can be described by amine absorption – desorption process of Figure 1, three major differences have to be mentioned as concerns corrosion risks evaluation, as illustrated in Table 2:

- gas composition and partial pressures,
- nature of the amine used,
- lean loading level.

In natural gas processing, the gas to be treated usually has high pressure up to 100 bar, and might contain a significant proportion of CO₂ and/or H₂S, up to several tens of percent. Oxygen contamination is not supposed

TABLE 2
Main differences between amine processes for natural gas treatment and CO₂ post-combustion capture

Parameter	Natural gas treatment	CO ₂ post-combustion capture
Gas composition	High P_{CO_2} (1-100 bar) No O ₂	Low P_{CO_2} (< 0.5 bar) 5-10% O ₂
Type of amine	Secondary or tertiary	Primary (MEA)
Lean loading level	< 0.1 mol _{CO₂} /mol _{amine}	0.25 mol _{CO₂} /mol _{amine}

to be present. The main goal of the process is to recover natural gas with a minimum amount of acid gas contaminants. Concerning H₂S, complete removal is usually expected, while CO₂ removal efficiency depends on the application (between 2-3% for conventional applications, but down to less than 50-100 ppmv for Liquefied Natural Gas, LNG). Optimisation of the process then allows using secondary or tertiary amines, and requires complete regeneration of the solvent, *i.e.* hardly no acid gas is present in the solvent at the outlet of the regenerator column, with a lean loading typically below 0.1 mol_{CO₂}/mol_{amine} [16].

On the other hand, CO₂ capture from combustion fumes responds to different constraints, and has slightly different objectives. The first important factor is in the composition and pressure of the gas to be treated. Usually, it contains up to 10-15% CO₂, for a total pressure close to 1 bar. The CO₂ partial pressure is then extremely low, while the emitted fumes flow-rate is extremely high. It is therefore required to have a solvent capable of a very fast absorption reaction with CO₂, which is generally the case of primary amines, but not secondary or tertiary amines. Additionally, the presence of up to 5% oxygen in the flue gas is also an important factor, since it might react with the amine to form corrosive degradation products. Lastly, operating conditions are aimed at finding a compromise between a good CO₂ removal, without penalising too much the power plant efficiency. For this reason, CO₂ regeneration is not complete in CO₂ capture processes: then, the lean amine loading is generally not zero, but preferably around 0.25 mol_{CO₂}/mol_{amine} in the case of MEA.

2 RECENT INVESTIGATIONS ON CORROSION IN CO₂ POST-COMBUSTION CAPTURE PROCESSES

2.1 Laboratory Studies on MEA

Several papers presenting laboratory corrosion measurements in MEA solutions have been published in the last years [21, 23, 25, 51, 52]. Most of these studies were




Figure 2

Typical polarization curves of carbon steel in MEA at different CO₂ loading (results taken in reference [52]).

performed in glass cells at moderate temperature (max. 80°C) and at ambient pressure, and used electrochemical measurements to examine the impact of several parameters on corrosion. Most of the time, corrosion rate was evaluated by extrapolating the cathodic region to the corrosion potential in order to determine the corrosion current density.

The electrochemical behaviour of carbon steel in 30% MEA solution at 80°C for different levels of CO₂ loading is illustrated in Figure 2. These results were taken in [52], where a detailed description of experimental conditions can be found. These curves are typical of an active corrosion behaviour. Both the cathodic and the anodic reaction rates are increased with an increase of CO₂ loading. A passive region is also observed at high overpotential, with a plateau current value increasing with CO₂ loading.

The impact of amine concentration was studied in [21, 25, 52]. At constant CO₂ loading, a weak increase of corrosion rate is observed when the MEA concentration is raised from 6 to 30% [25]. At higher

concentration, between 30% and 55% MEA, polarisation curves show very similar corrosion rates [21, 52].

This weak impact of MEA concentration on corrosion might sound contradictory with past experience of natural gas treatment, where a classical rule-of-thumb indicates that MEA should not exceed 20-30% [15, 53]. However, it is also well admitted that concentrated amine solutions are more prone to degradation, forming corrosive by-products [53, 54]. Therefore, the increased corrosivity with amine concentration is more a consequence of increased degradation than an intrinsic property of concentrated solutions.

The impact of temperature on corrosion in MEA was mainly evaluated between ambient temperature and 80°C in laboratory conditions. As expected, the rate of electrochemical reactions increases with temperature. Both the cathodic and anodic reactions are affected [21, 25, 52, 54]. This result is a typical consequence of thermally activated electrochemical reactions.

The impact of CO₂ loading is usually considered as the most influencing parameter. As illustrated in Figure 2, the evolution of acid gas loading from 0 to 0.5 induces a tenfold increase of the corrosion current density. CO₂ loading affects both electrochemical reactions, but the impact is more pronounced on the cathodic side [21, 23, 25, 51, 52].

A few other studies focussed on the impact of impurities, *i.e.* oxygen [21, 25, 51, 52], HSS [35, 51, 55], SO₂ and NO₂ [56, 57]. All these impurities were found to be detrimental to corrosion, by an increase of the rates of electrochemical reactions. HSS is also known to decrease the protectivity of corrosion scale by a chelating effect. Concerning SO₂ and NO₂, the main impact is probably on amine degradation rather than on corrosion.

For all these impurities, it can be concluded that the amplitude of corrosion rate increase remains of second order in comparison with the impact of CO₂ loading and temperature.

A synthetic view of the evolution of carbon steel corrosion rate with CO₂ loading and temperature is presented in Figure 3 [52]. At a given CO₂ loading, it appears quite clearly that the corrosion rate follows a linear evolution with the reciprocal of temperature, confirming thermal activation. From this diagram, corrosion rates can be estimated at any temperature and CO₂ loading encountered in the unit. It appears that even in the presumably least severe conditions, *i.e.* moderate temperature (50°C) and lean loading (0.25 mol_{CO₂}/mol_{amine}), carbon steel corrosion still exceeds 100 µm/year. On the other hand, in the hot rich amine, corrosion rate above several mm/year is predicted, and this level was confirmed by pilot plant experiments [58].




Figure 3

Impact of temperature and CO₂ loading on the corrosion rate of carbon steel in 30% MEA [52].

From all laboratory studies, it appears that carbon steel grades cannot be used safely in all operating conditions encountered in a MEA capture unit.

It also appears from most laboratory studies that austenitic stainless steel grade 316L seems to perform well [35, 52].

2.2 Corrosion Prevention Strategies

Two alternatives are usually considered as corrosion protection measures. The first one consists in the addition of corrosion inhibitors. Use of corrosion inhibitors is often recommended when the operator wants to minimise investment costs and make most components from carbon steel. The second alternative consists in using stainless steel grades in those parts of the plant exposed to extremely corrosive conditions. Although investment costs are usually increased, it allows reducing operational costs, and permits more versatility. Advantages and drawbacks of these two options for CO₂ capture units are discussed below.

Corrosion inhibition is commonly used in acid gas treatment plants, where it often allows using carbon steel grades rather than more expensive alloys. Two types of inhibitors are found.

Oxidizing passivators react electrochemically with the steel surface to promote the formation of a stable protective passive layer. Most of the time, these inhibitors consist of inorganic molecules. For gas sweetening applications, they are usually presented as the most

efficient [20, 59]. Sodium metavanadate is probably the most cited molecule, and the first patents for gas treatment applications date 1936, in US patent No. 2.031.632. Positive feedback from field experience was reported in [11], about a MEA unit in a hydrogen refining plant. Other salts of heavy metals can be used, like antimony, cobalt, bismuth or nickel. However, these types of inhibitors are largely becoming obsolete, mainly because of high toxicity and the cost of waste disposal. As a more environmental friendly alternative, copper salts are also known to inhibit corrosion in amine units. The first reference to this property was found in US patent No. 2.377.966 issued in 1945. However, inhibiting corrosion with copper salts presents some difficulty for application in CO₂ capture plants due to the high concentration of oxygen in the gas. Indeed, a catalysis of amine oxidative degradation can be caused by such salts of heavy metals [60, 61]. Furthermore, in the stripper section where dissolved oxygen vanishes, precipitation of metallic copper might happen, causing severe bimetallic corrosion and consumption of the inhibitor [62]. In spite of these problems, copper carbonate and sodium metavanadate are often used as reference inhibitors in recent studies for CO₂ capture with MEA. The excellent performance of both products was confirmed in [62-65]. It was confirmed, however, that in the absence of oxygen, copper carbonate was less efficient and a pitting tendency could be observed, associated with the precipitation of metallic copper on steel surfaces [62].

Film forming inhibitors represent the other family of molecules commonly used for gas treatment applications. This type of molecules adsorbs on the steel surface to form a thin layer which impedes access of the corrosive solution to the surface. However, for this specific application, they are considered to be less efficient than inorganic compounds [20, 59]. For CO₂ capture application, investigation on low-toxic organic inhibitors with promising results was proposed in [65]. However, it was concluded that none of the tested molecules was as efficient as sodium metavanadate.

Although a few companies propose processes including corrosion inhibitors [66], the most followed strategy is to use corrosion resistant alloys in those parts of the plant exposed to extremely corrosive conditions. For acid gas treatment units, it is therefore recommended to use stainless steel at least in the rich amine parts of the unit. However, some authors recommend stainless steel even in lean solvent sections [26, 46, 67-69], in order to operate at higher flow-rates, and also to provide versatility to the unit for easier solvent swapping.

In the case of CO₂ capture with MEA, carbon steel presents high levels of corrosion in the entire parts of the plant, either rich or lean solvent sections as

illustrated in Figure 3. Therefore, stainless steel represents an interesting alternative when one wants to avoid using proprietary and often ecotoxic inhibitors. Furthermore, most industrial applications to date consist in demonstration pilot plants, for which versatility is a premium requirement. To serve this demand, using corrosion resistant grades allows easier solvent swap for benchmark studies with new solvents.

2.3 Corrosion Aspects in the Development of New Solvents

CO₂ capture by 30% MEA represents the reference technology for post-combustion applications. However, it is well admitted that the cost of CO₂ removal with this process is too high, and needs to be reduced.

Thus, a lot of research programs aims at developing new solvents, with a particular focus on the energy consumption needed at regeneration step. Minimizing solvent degradation is also often considered as the second immediate priority. Even if this research is usually not driven by corrosion aspects, testing the corrosivity of new molecules is often considered at the early stages of research and development efforts, and a few papers were found in the recent literature.

An extensive study on more than 20 amines including degradation and corrosion evaluations was proposed by Martin *et al.* [70]. Molecules with a greater stability and less corrosivity than MEA were identified, and a Quantitative Structure Property Relationship (QSPR) model was built that can be applied to predict degradation.

Solutions composed of MEA and piperazine were tested in [71]. Such solutions showed more corrosion than in pure MEA.

A great deal of attention is also given to activated solutions of tertiary amines. MDEA using piperazine as activator is one of the favourite subject of investigation in the recent years [72-74]. Corrosion in this type of solution was studied in [75], showing the same detrimental impact of CO₂ loading and temperature as already observed in MEA or in other amine solutions.

Sterically hindered amines have also received a great deal of attention due to good performances in terms of absorption and desorption capacity. It is also thought that sterical-hindrance might limit the interactions between the amine and the steel surface, thus reducing the corrosivity. Investigation of AMP (2-Amino-2-Methyl-1-Propanol) was proposed in [65]. In comparison with MEA, AMP shows less corrosivity at elevated temperature and in lean loading conditions.

Other good corrosion performances were mentioned in several papers presenting new proprietary solvents, without a precise description of the amine nature.

This is the case of the DMXtm amine developed by IFP Energies nouvelles, showing carbon steel corrosion below 10 $\mu\text{m}/\text{year}$ at temperature up to 160°C in CO₂ loaded conditions [76].

2.4 Corrosion Monitoring at Pilot Plant Scale

Corrosion evaluation at the pilot scale was performed at several locations worldwide. MEA 30% is usually used as benchmark solvent, to which newly developed solvents with promising features are compared.

The CASTOR pilot plant, located in Denmark at a coal-fired power station was used for process evaluations with MEA and other proprietary solvents [77]. Corrosion monitoring was performed with weight loss coupons at different locations in the pilot plant. Carbon steel corrosion at a rate exceeding millimeters' per years was found at the outlet of the stripper with 30% MEA. During the same study, stainless steel grades (304L and 316L) performed extremely well, without significant weight loss corrosion [58]. In the same paper, results obtained on the ITC pilot plant from the University of Regina (Canada) were also presented, confirming that corrosion in 30% MEA was the highest in the rich section from the heat exchanger to the stripper. This pilot plant also revealed corrosion in the stripper overhead, where CO₂ saturated water is subject to condensation.

Other corrosion results in pilot plants operated with 30% MEA were recently published. Different types of stainless steels and polymeric materials as well as concrete were tested in the lignite-fired Niederaussem power station (Germany) [78, 79]. Carbon steel corrosion was evaluated in the Tarong coal-fired power station (Australia), confirming once more the high corrosivity of the rich MEA [80]. Similar results were also obtained in the Brindisi pilot plant (Italy) [81].

Another study presented pilot plant experiments on a proprietary solvent specified by *Toshiba*. It was found that the corrosion rate in this solvent was the highest in the rich amine section, similarly as in MEA or other amines [82]. It was shown also that corrosion and amine degradation was increased when SO₂ was present in the flue gas [83].

3 CONSEQUENCES FOR CO₂ TRANSPORT AND STORAGE

Another important aspect of the CO₂ Capture and Storage (CCS) chain is the transport of CO₂ from the post-combustion capture unit to the storage site. Most of the time, dense phase CO₂ at pressure above 100 bar will

circulate in a pipeline network. Transportation of high pressure dry CO₂ through carbon steel pipelines is commonly used for enhanced oil recovery for more than several decades, with extremely positive feedback. As long as the water content is maintained below saturation, corrosion will be insignificant. On the other hand, as soon as free water can condensate, it is highly concentrated in CO₂ and extremely rapid and localised corrosion can occur in range above 10 mm/year. Based on the good experience of Enhanced Oil Recovery (EOR), it has long been considered that transportation of post-combustion CO₂ was not a major issue, and this area received much less attention and funding for R&D programs. However, recent publications showed that it was not as straightforward, and that corrosion risks had to be examined carefully [84-97]. Indeed, it appears that water solubility in dense phase CO₂ is strongly modified in presence of impurities like SO_x and NO_x, or O₂. Furthermore, when SO₂ is present with water and oxygen, extremely corrosive sulphuric acid might form.

Understanding the impact of all impurities present in the CO₂ after post-combustion capture on water solubility is therefore a major task in order to develop CCS safely. At the present time, there are no commonly accepted specifications for the maximum levels of impurities required for pipeline transport. Some recommendations were proposed after two European projects within the sixth framework programme (FP6), *Dynamis*¹ and *Encap*², and often referred as *Dynamis* CO₂ quality recommendations (*Tab. 3*) [98, 99]. These recommendations were established from a set of criteria, including health and safety, operation and design, but it was acknowledged that “the mechanisms of the water related corrosion for CO₂ pipelines of carbon steel are not fully understood”. As an illustration, several experimental studies have been carried out below or close to the the *Dynamis* recommendations, and showed some risks of corrosion.

According to Dugstad *et al.* [91] water solubility in pure CO₂ at 100 bar and in the temperature range 4-25°C exceeds 1 900 ppmv. This was confirmed by corrosion experiments in pure CO₂ with 500 ppm to 1 200 ppm H₂O, giving no corrosion of carbon steel coupons. However, when 500 ppmv H₂O and 100 ppmv NO₂ is present, the corrosion rate was high (> 0.1 mm/year). Considering several impurities at the same time, these authors also showed that corrosion could take place with as low as 200 ppmv H₂O when SO₂ and O₂ were present [94].

¹ Project website www.dynamis-hypogen.com.

² Project website www.encapCO2.org.

TABLE 3
Dynamis CO₂ quality recommendations (concentrations in ppmv) [98, 99]

Component	Concentration	Limitation
H ₂ O	500 ppm	Design and operational considerations
H ₂ S	200 ppm	Health and safety considerations
CO	2 000 ppm	Health and safety considerations
CH ₄	Storage in aquifer: 4%EOR: 100-1 000 ppm	As proposed in ENCAP project
N ₂	4%	As proposed in ENCAP project
Ar	4%	As proposed in ENCAP project
H ₂	4%	Further reduction of H ₂ is recommended because of its energy content
SO _x	100 ppm	Health and safety considerations
NO _x	100 ppm	Health and safety considerations
CO ₂	> 95.5%	

It seems therefore essential to continue to work on the impact of impurities on high pressure CO₂ corrosion, to gain more confidence in CO₂ quality recommendations.

Lastly, after CO₂ transport through a pipeline network, underground injection might inevitably put free water in contact with high pressure CO₂ and impurities. In this situation, corrosion rate of carbon steel easily reaches several tens of mm/year, and even some corrosion resistant alloys might suffer corrosion above hundreds of μm/year [84, 96].

CONCLUSIONS

Corrosion issues are encountered in the whole CCS chain.

In the CO₂ post-combustion capture process, the corrosive environment mainly consists of aqueous amine. Identification of corrosion risks and mitigation strategies benefit from several decades experience of natural gas treatment with amines. Nevertheless, important differences have to be kept in mind. Currently, the most widespread process uses primary amines which are the more prone to degradation and corrosion, in comparison with secondary or tertiary amines. For this process using MEA, current challenges consist in limiting the degradation by oxygen, and to mitigate corrosion of the installation.

It was shown also that corrosion is often taken into account at the early stages of research programmes dedicated to new molecules. Laboratory tools and pilot plants equipped with corrosion monitoring devices are helpful for this purpose.

Impact on corrosion of impurities in the post-combustion CO₂ was also emphasized. Commonly accepted recommendations for the composition of CO₂ might not provide complete assurance of the absence of corrosion of steel pipelines used for transport. More work has to be done to predict the impact of impurities on water solubility.

At the very end of the chain, it was shown also that formation water and supercritical CO₂ might combine to form a very corrosive environment for the injection facilities.

For both transport and storage steps, experience from EOR and oil and gas production should be put to good advantage to find appropriate mitigation strategies. Nevertheless, it seems important also to address the specificities of high pressure CO₂ coming from the capture process, and especially the impact of impurities.

REFERENCES

- 1 Kohl A.L., Nielsen R.B. (1997) *Gas Purification*, fifth edition, Gulf Publishing Company, Houston, Texas.
- 2 Bouillon P.A., Carrette P.L., Faraj A., Lemaire E., Raynal L. (2011) IFPEN solutions for lowering the cost of post-combustion CO₂ capture, *ICCDU International Conference on Carbon Dioxide Utilization*, 27-30 June, Dijon, France.
- 3 Tems R., Al-Zahrani A. (2006) Cost of corrosion in gas sweetening and fractionation plants, *Corrosion/2006*, Paper No. 444, NACE International.
- 4 Dingman J.C., Allen D.L., Moore T.F. (1966) Minimize corrosion in MEA units, *Hydrocarbon Processing* **45**, (9), 570-575.
- 5 Lang F.S., Mason J.F. (1958) Corrosion in amine gas treating solutions, *Corrosion* **14**, (2), 65-68.

- 6 Montrone E.D., Long W.P. (1971) Choosing materials for CO₂ absorption systems, *Chemical Engineering*, Jan. 25.
- 7 Polderman L.D., Dillon C.P., Steele A.B. (1955) Degradation of monoethanolamine in natural gas treating service, *Oil Gas Journal* **16**, (5), 180-183.
- 8 Riesenfeld F.C., Blohm C.L. (1950) Corrosion problems in gas purification units employing MEA solutions, *Petroleum Refiner* **20**, (4), 141-150.
- 9 Riesenfeld F.C., Hugues C.L. (1951) Corrosion in amine gas treating plants, *Petroleum Refiner* **30**, (2), 97-106.
- 10 Riesenfeld F.C., Blohm C.L. (1951) Corrosion resistance of alloys in amine gas treating systems, *Petroleum Refiner* **30**, (10), 107-115.
- 11 Williams E., Leckie H.P. (1968) Corrosion and its prevention in a monoethanolamine gas treating plant, *Materials Protection* **7**, (7), 321-326.
- 12 McHenry H.I., Read D.T., Shives T.R. (1987) Failure analysis of an amine-absorber pressure vessel, *Materials Performance* **26**, (8), 18-24.
- 13 Richert J.P., Bagdasarian A.J., Shargay C.A. (1987) Stress corrosion cracking of carbon steel in amine systems, *Corrosion/87*, Paper No. 187, NACE International.
- 14 Richert J.P., Bagdasarian A.J., Shargay C.A. (1989) Extent of stress corrosion cracking in amine plants revealed by survey, *Oil Gas Journal* **5**, 45-52.
- 15 Nielsen R.B., Lewis K.R., McCullough J.G., Hansen D.A. (1995) Controlling corrosion in amine treating plants, Proceedings of the *Laurance Reid Gas Conditioning Conference*, Norman, Oklahoma.
- 16 Nielsen R.B., Lewis K.R., McCullough J.G., Hansen D.A. (1995) Corrosion in refinery amine systems, *Corrosion/95*, Paper No. 571, NACE International.
- 17 EFC (2003) Publication No. 46, Avoiding environmental cracking in amine units, The European Federation of Corrosion, *Woodhead Publishing Ltd*, Cambridge, England.
- 18 Dupart M.S., Bacon T.R., Edwards D.J. (1993) Understanding corrosion in alkanolamine gas treating plants. 1. proper mechanism diagnosis optimizes amine operations, *Hydrocarbon Processing* **72**, 75-79.
- 19 Dupart M.S., Bacon T.R., Edwards D.J. (1993) Understanding corrosion in alkanolamine gas treating plants. 2. Case histories show actual plant problems and their solutions, *Hydrocarbon Processing* **72**, 89-94.
- 20 Kosseim A.J., McCullough J.G., Butwell K.F. (1984) Corrosion-Inhibited Amine Guard St Process, *Chemical Engineering Progress* **80**, 64-71.
- 21 Soosaiprakasam I.R., Veawab A. (2008) Corrosion and polarization behavior of carbon steel in MEA-based CO₂ capture process, *International Journal of Greenhouse Gas Control* **2**, (4), 553-562.
- 22 Tomoe Y., Shimizu M., Kaneta H. (1996) Active dissolution and natural passivation of carbon steel in carbon dioxide loaded alkanolamine solutions, *Corrosion/96*, Paper No. 395, NACE International.
- 23 Veawab A., Aroonwilas A. (2002) Identification of oxidizing agents in aqueous amine-CO₂ systems using a mechanistic corrosion model, *Corrosion Science* **44**, (5), 967-987.
- 24 Bich N.N., Vacha F., Schubert R. (1996) Corrosion in MDEA sour gas treating plants: correlation between laboratory testing and field experience, *Corrosion/96*, Paper No. 392, NACE International.
- 25 Veawab A., Tontiwachwuthikul P., Chakma A. (1999) Corrosion behavior of carbon steel in the CO₂ absorption process using aqueous amine solutions, *Industrial Engineering Chemistry Research* **38**, (10), 3917-3924.
- 26 Bonis M.R., Ballaguet J.P., Rigail C. (2004) A critical look at amines: a practical review of corrosion experience over four decades, *83rd annual GPA convention*, 14-17 March, New-Orleans, LO.
- 27 Blanc C., Grall M., Demarais G. (1982) The part played by degradation products in the corrosion of gas sweetening plants using DEA and MDEA, Proceedings of the *Laurance Reid Gas Conditioning Conference*, 8-10 March, Norman, OK.
- 28 DuPart M.S., Rooney P.C., Bacon T.R. (1999) Comparing laboratory and plant data for MDEA/DEA blends, *Hydrocarbon Processing* **78**, (4), 81-86.
- 29 DuPart M.S., Rooney P.C., Bacon T.R. (1999) Comparison of laboratory and operating plant data of MDEA/DEA blends, Proceedings of the *49th Laurance Reid Gas Conditioning Conference*, 21-24 Feb., Norman, OK.
- 30 Veldman R.R. (2000) Alkanolamine solution corrosion mechanisms and inhibition from heat stable salts and CO₂, *Corrosion/2000*, Paper No. 496, NACE International.
- 31 Guo X.P., Tomoe Y. (1999) The effect of corrosion product layers on the anodic and cathodic reactions of carbon steel in CO₂-saturated MDEA solutions at 100°C, *Corrosion Science* **41**, (7), 1391-1402.
- 32 Vazquez R.C., Rios G., Trejo A., Rincon R.E., Uruchurtu J., Malo J.M. (2000) The effect of diethanolamine solution concentration in the corrosion of steel, *Corrosion/2000*, paper No. 696, NACE International.
- 33 Rooney P.C., Bacon T.R., DuPart M.S. (1996) Effect of heat stable salts on MDEA solution corrosivity, *Hydrocarbon Processing* **75**, (3), 95-103.
- 34 Rooney P.C., DuPart M.S., Bacon T.R. (1997) Effect of heat stable salts on MDEA solution corrosivity .2, *Hydrocarbon Processing* **76**, (4), 65-71.
- 35 Tanthapanichakoon W., Veawab A., McGarvey B. (2006) Electrochemical investigation on the effect of heat-stable salts on corrosion in CO₂ capture plants using aqueous solution of MEA, *Industrial Engineering Chemistry Research* **45**, (8), 2586-2593.
- 36 Al-Zahrani A., Al-Luqmaun S.I. (2006) Methodology of mitigating corrosion mechanisms in amine gas treating units, *Corrosion/2006*, Paper No. 441, NACE International.
- 37 Raut N., Chaudhari R.M., Naik V.S. (2009) Failure of amine regenerating column of amine treatment unit, *Corrosion/2009*, Paper No. 334, NACE International.
- 38 Xie J., Simanzhenkov V., Santos B., Ikeda K., Davies L. (2010) Corrosion of UNS S30403 stainless steel trays in an amine unit, *Corrosion/2010*, Paper No. 187, NACE International.
- 39 Moore M.A., Qarni M.M., Lobley G.R. (2008) Corrosion problems in gas treating systems, *Corrosion/2008*, Paper No. 08419, NACE International.

- 40 Safruddin S., Safruddin R. (2000) Twenty years experience in controlling corrosion in amine unit, Badak LNG plant, *Corrosion/2000*, Paper No. 497, NACE International.
- 41 Howard M., Sargent A. (2001) Operating experiences at Duke energy field services Wilcox plant with oxygen contamination and amine degradation, Proceedings of the 51st Laurance Reid Gas Conditioning Conference, 25-28 Feb., Norman, OK.
- 42 Kane R.D., Wilhelm S.M., Oldfield J.W. (1989) Review of hydrogen induced cracking of steels in wet H₂S refinery service, *Materials Property Council*, 28 March, Paris, France.
- 43 Teevens P.J. (1990) Toward a better understanding of the cracking behavior of carbon steel in alkanolamine sour gas sweetening units: its detection, monitoring and how to avoid it, *Corrosion/90*, Paper No. 198, NACE International.
- 44 DeHart T.R., Hansen D.A., Mariz C.L., McCullough J.G. (1999) Solving corrosion problems at the NEA Bellingham Massachusetts carbon dioxide recovery plant, *Corrosion/99*, Paper No. 264, NACE International.
- 45 Dupart M.S., Bacon T.R., Edwards D.J. (1991) Understanding and preventing corrosion in alkanolamine gas treating plants, Proceedings of the 41st Laurance Reid Gas Conditioning Conference, 4-6 March, Norman, OK.
- 46 Kittel J., Bonis M.R., Perdu G. (2008) Corrosion control on amine plants: new compact unit design for high acid gas loadings, *Sour Oil & Gas Advanced Technology Conference*, 27 April-1 May, Abu Dhabi, UAE.
- 47 Pearson H., Shao J., Norton D., Dandekar S. (2005) Case study of effects of bicine in CO₂ only amine treater service, Proceedings of the 55th Laurance Reid Gas Conditioning Conference, Norman, OK.
- 48 Fan D., Kolp L.E., Huett D.S., Sargent M.A. (2000) Role of impurities and H₂S in refinery lean DEA system corrosion, *Corrosion/2000*, Paper No. 495, NACE International.
- 49 Tomoe Y., Miyata K., Ihara M., Masuda K., Efirid K.D. (2002) Evaluation of corrosion resistance of metallic materials for DGA regenerators in dynamic conditions, *Corrosion/2002*, Paper No. 350, NACE International.
- 50 Jordan T.J., Nozal P.J., Azodi A. (2006) Handling trace oxygen at the saunders gas processing facility, Proceedings of the 56th Laurance Reid Gas Conditioning Conference, Norman, OK.
- 51 Fleury E., Kittel J., Vuillemin B., Oltra R., Ropital F. (2008) Corrosion in amine solvents used for the removal of acid gases, *Eurocorr 2008*, The European Federation of Corrosion, Edinburgh, UK, 7-11 Sept.
- 52 Kittel J., Fleury E., Vuillemin B., Gonzalez S., Ropital F., Oltra R. (2012) Corrosion in alkanolamine used for acid gas removal: From natural gas processing to CO₂ capture, *Materials and Corrosion* **63**, (3), 223-230.
- 53 Wagner R., Judd B. (2006) Fundamentals - Gas sweetening, Proceedings of the 56th Laurance Reid Gas Conditioning Conference, Norman, OK.
- 54 Lawal A.O., Idem R.O. (2006) Kinetics of the oxidative degradation of CO₂ loaded and concentrated aqueous MEA-MDEA blends during CO₂ absorption from flue gas streams, *Industrial Engineering Chemistry Research* **45**, (8), 2601-2607.
- 55 Duan D., Choi Y.S., Nescic S., Vitse F., Bedell S.A., Worley C. (2010) Effect of oxygen and heat stable salts on the corrosion of carbon steel in MDEA-based CO₂ capture process, *Corrosion/2010*, Paper No. 191, NACE International.
- 56 Kladkaew N., Idem R., Tontiwachwuthikul P., Saiwan C. (2009) Corrosion Behavior of Carbon Steel in the Monoethanolamine-H₂O-CO₂-O₂-SO₂ System: Products, Reaction Pathways, and Kinetics, *Industrial Engineering Chemistry Research* **48**, (23), 10169-10179.
- 57 Kladkaew N., Idem R., Tontiwachwuthikul P., Saiwan C. (2009) Corrosion Behavior of Carbon Steel in the Monoethanolamine-H₂O-CO₂-O₂-SO₂ System, *Industrial & Engineering Chemistry Research* **48**, (19), 8913-8919.
- 58 Kittel J., Idem R., Gelowitz D., Tontiwachwuthikul P., Parrain G., Bonneau A. (2009) Corrosion in MEA units for CO₂ capture: Pilot plant studies, *Energy Procedia* **1**, (1), 791-797.
- 59 Pearce B., DuPart M.S. (1987) Corrosion in gas conditioning plants - An overview, *Corrosion/87*, Paper No. 39, NACE International.
- 60 Bello A., Idem R.O. (2006) Comprehensive study of the kinetics of the oxidative degradation of CO₂ loaded and concentrated aqueous monoethanolamine (MEA) with and without sodium metavanadate during CO₂ absorption from flue gases, *Industrial Engineering Chemistry Research* **45**, (8), 2569-2579.
- 61 Goff G.S., Rochelle G.T. (2006) Oxidation inhibitors for copper and iron catalyzed degradation of monoethanolamine in CO₂ capture processes, *Industrial Engineering Chemistry Research* **45**, (8), 2513-2521.
- 62 Soosaiprakasam I.R., Veawab A. (2009) Corrosion inhibition performance of copper carbonate in MEA- CO₂ capture unit, *Energy Procedia* **1**, (1), 225-229.
- 63 Soosaiprakasam I.R., Veawab A. (2007) Inhibition performance of copper carbonate in CO₂ absorption process using aqueous MEA, *Corrosion/2007*, Paper No. 396, NACE International.
- 64 Tanthapanichakoon W., Veawab A. (2005) Polarization behavior and performance of inorganic corrosion inhibitors in monoethanolamine solution containing carbon dioxide and heat-stable salts, *Corrosion* **61**, (4), 371-380.
- 65 Veawab A., Tontiwachwuthikul P. (2001) Investigation of low-toxic organic corrosion inhibitors for CO₂ separation process using aqueous MEA solvent, *Industrial Engineering Chemistry Research* **40**, (22), 4771-4777.
- 66 Reddy S., Johnson D., Gilmartin J. (2008) Fluor's econamine FG plus technology for CO₂ capture at coal-fired power plants, *Power Plant Air Pollutant Control Mega Symposium*, Baltimore, MD, 25-28 Aug.
- 67 Rennie S. (2006) Corrosion and materials selection for amine service, *Materials and Testing Conference*, Fremantle, Australia, 30 Oct.-2 Nov.
- 68 Rooney P.C., DuPart M.S. (2000) Corrosion in alkanolamine plants: causes and minimization, *Corrosion/2000*, Paper No. 494, NACE International.
- 69 Titz J.T., Asprien N., Katz T., Wagner R. (2003) Corrosion in amine solutions used for acid gas removal, Proceedings of the 53rd Laurance Reid Gas Conditioning Conference, Norman, OK.

- 70 Martin S., Lepaumier H., Picq D., Kittel J., de Bruin T., Faraj A., Carrette P.L. (2012) New amines for CO₂ capture. IV. Degradation, corrosion, and quantitative structure property relationship model, *Industrial Engineering Chemistry Research* **51**, (18), 6283-6289.
- 71 Nainar M., Veawab A. (2009) Corrosion in CO₂ capture process using blended monoethanolamine and piperazine, *Industrial Engineering Chemistry Research* **48**, (20), 9299-9306.
- 72 Ali B.S., Aroua M.K. (2004) Effect of piperazine on CO₂ loading in aqueous solutions of MDEA at low pressure, *International Journal Thermophysics* **25**, (6), 1863-1870.
- 73 Bishnoi S., Rochelle G.T. (2002) Absorption of carbon dioxide in aqueous piperazine/methyldiethanolamine, *AIChE Journal* **48**, (12), 2788-2799.
- 74 Derks P.W.J., Hogendoorn J.A., Versteeg G.F. (2006) Absorption of carbon dioxide into aqueous solutions of MDEA and piperazine, *CHISA 2006 – 17th International Congress of Chemical and Process Engineering*, Prague, Czech Republic, 27-31 August.
- 75 Zhao B., Sun Y., Yuan Y., Gao J., Wang S., Zhuo Y., Chen C. (2011) Study on corrosion in CO₂ chemical absorption process using amine solution, *Energy Procedia* **4**, 93-100.
- 76 Kittel J., Gonzalez S., Lemaire E., Raynal L. (2012) Corrosion in post-combustion CO₂ capture plants - comparisons between MEA 30% and new processes, *Eurocorr 2012*, The European Federation of Corrosion, Istanbul.
- 77 Knudsen J.N., Jensen J.R.N., Vilhelmsen P.J., Biede O. (2009) Experience with CO₂ capture from coal flue gas in pilot-scale: Testing of different amine solvents, *Energy Procedia* **1**, (1), 783-790.
- 78 Moser P., Schmidt S., Sieder G., Garcia H., Stoffregen T. (2011) Performance of MEA in a long-term test at the post-combustion capture pilot plant in Niederaussem, *International Journal of Greenhouse Gas Control* **5**, (4), 620-627.
- 79 Moser P., Schmidt S., Uerlings R., Sieder G., Titz J.T., Hahn A., Stoffregen T. (2011) Material testing for future commercial post-combustion capture plants. Results of the testing programme conducted at the Niederaussem pilot plant, *Energy Procedia* **4**, 1317-1322.
- 80 Pearson P., Cousins A., Cottrell A.J., Duncombe B., Feron P.H.M., Hollenkamp T.F., Huang S., Meuleman E. (2013) Corrosion in amine post combustion capture plants, *Eurocorr 2012*, The European Federation of Corrosion, Istanbul.
- 81 Lemaire E., Bouillon P.A., Mangiaracina A., Normand L., Laborie G. (2012) Results of the 2.25 t/h post-combustion CO₂ capture pilot plant of ENEL at the Brindisi coal power plant and last R&D developments for Hicapt⁺ process, *SOGAT - CO₂ forum*, Abu-Dhabi, UAE, 29 March.
- 82 Gao J., Wang S., Sun C., Zhao B., Chen C. (2012) Corrosion behavior of carbon steel at typical positions of an amine-based CO₂ capture pilot plant, *Industrial Engineering Chemistry Research* **51**, (19), 6714-6721.
- 83 Gao J., Wang S., Zhou S., Zhao B., Chen C. (2011) Corrosion and degradation performance of novel absorbent for CO₂ capture in pilot-scale, *Energy Procedia* **4**, 1534-1541.
- 84 Zhang X., Zevenbergen J., Spruijt M.P.N., Benedictus T. (2012) Corrosion of steels in CO₂ transport and storage environments, *Eurocorr 2012*, The European Federation of Corrosion, Istanbul.
- 85 Xiang Y., Wang Z., Yang X., Li Z., Ni W. (2012) The upper limit of moisture content for supercritical CO₂ pipeline transport, *Journal Supercritical Fluids* **67**, (7), 14-21.
- 86 Xiang Y., Wang Z., Xu C., Zhou C., Li Z., Ni W. (2011) Impact of SO₂ concentration on the corrosion rate of X70 steel and iron in water-saturated supercritical CO₂ mixed with SO₂, *Journal Supercritical Fluids* **58**, (2), 286-294.
- 87 Xiang Y., Wang Z., Yang X., Ni W., Li Z. (2011) Corrosion behavior of X70 steel in the supercritical CO₂ mixed with SO₂ and saturated water, *Proceedings of the Twenty-first International Offshore and Polar Engineering Conference*, Maui, Hawaii, USA, 19-24 June.
- 88 Ruhl A.S., Kranzmann A. (2012) Corrosion behavior of various steels in a continuous flow of carbon dioxide containing impurities, *International Journal Greenhouse Gas Control* **9**, (7), 85-90.
- 89 Lucci A., Demofonti G., Spinelli C.M. (2011) CO₂ anthropogenic pipeline transportation, *Proceedings of the Twenty-first International Offshore and Polar Engineering Conference*, Maui, Hawaii, USA, 19-24 June.
- 90 Farelas F., Choi Y.S., Nescic S. (2012) Effects of CO₂ phase change, SO₂ content and flow on the corrosion of CO₂ transmission pipeline steel, *Corrosion/2012*, NACE International, C2012-0001322.
- 91 Dugstad A., Halseid M., Morland B., Siversten A.O. (2012) Corrosion in dense phase CO₂ with small amounts of SO₂, NO₂ and water, *Eurocorr 2012*, The European Federation of Corrosion, Istanbul.
- 92 Dugstad A., Halseid M. (2012) Internal corrosion in dense phase CO₂ transport pipelines - State of the art and the need for further R&D, *Corrosion/2012*, Paper No. 1452, NACE International, *Corrosion 2012*, Salt Lake City, Utah, 11-15 March.
- 93 Dugstad A., Morland B., Clausen S. (2011) Corrosion of transport pipelines for CO₂ - Effect of water ingress, *Energy Procedia* **4**, 3063-3070.
- 94 Dugstad A., Clausen S., Morland B. (2011) Transport of dense phase CO₂ in C-steel pipelines- When is corrosion an issue? *Corrosion/2011*, Paper No. 70, NACE International.
- 95 Dugstad A., Halseid M., Morland B. (2011) Corrosion in dense phase CO₂ pipelines - State of the art, *Eurocorr 2011*, The European Federation of Corrosion, Stockholm.
- 96 Choi Y.S., Nescic S. (2011) Effect of water content on the corrosion behavior of carbon steel in supercritical CO₂ phase with impurities, *Corrosion/2011*, Paper No. 377, NACE International.
- 97 Chambers B., Kane R., Yunovich M. (2010) Corrosion and selection of alloys for carbon capture and storage (CCS) systems: Current challenges, *SPE International Conference on CO₂ capture, storage and utilization*, The New-Orleans, LO, 10-12 Nov.

- 98 de Visser E., Hendriks C., Barrio M., Mølnevik M.J., de Koeijer G., Liljemark S., Le Gallo Y. (2008) Dynamis CO₂ quality recommendations, *International Journal Greenhouse Gas Control* **2**, (4), 478-484.
- 99 de Visser E., Hendriks C., de Koeijer G., Liljemark S., Barrio M., Austegard A., Brown A. (2007) Dynamis CO₂ recommendations, FP6 European Project No. 019672 report No. D3.1.3.

Manuscript accepted in June 2013

Published online in November 2013

Copyright © 2013 IFP Energies nouvelles

Permission to make digital or hard copies of part or all of this work for personal or classroom use is granted without fee provided that copies are not made or distributed for profit or commercial advantage and that copies bear this notice and the full citation on the first page. Copyrights for components of this work owned by others than IFP Energies nouvelles must be honored. Abstracting with credit is permitted. To copy otherwise, to republish, to post on servers, or to redistribute to lists, requires prior specific permission and/or a fee: Request permission from Information Mission, IFP Energies nouvelles, fax. +33 1 47 52 70 96, or revueogst@ifpen.fr.