

Measuring Inorganics in Biomass fast Pyrolysis Oils

Charles-Philippe Lienemann, Alain Quignard, Nathalie Texier, Nadège Charon

▶ To cite this version:

Charles-Philippe Lienemann, Alain Quignard, Nathalie Texier, Nadège Charon. Measuring Inorganics in Biomass fast Pyrolysis Oils. Journal of Analytical and Applied Pyrolysis, 2021, 159, pp.105313. 10.1016/j.jaap.2021.105313 . hal-03432756

HAL Id: hal-03432756 https://ifp.hal.science/hal-03432756

Submitted on 17 Nov 2021

HAL is a multi-disciplinary open access archive for the deposit and dissemination of scientific research documents, whether they are published or not. The documents may come from teaching and research institutions in France or abroad, or from public or private research centers. L'archive ouverte pluridisciplinaire **HAL**, est destinée au dépôt et à la diffusion de documents scientifiques de niveau recherche, publiés ou non, émanant des établissements d'enseignement et de recherche français ou étrangers, des laboratoires publics ou privés.

¹ Measuring inorganics in biomass fast pyrolysis oils

2 Charles-Philippe LIENEMANN, Alain QUIGNARD, Nathalie TEXIER, Nadège CHARON

- 3 IFP Energies nouvelles, Rond-point de l'échangeur de Solaize, BP3, 69360 Solaize, France
- 4

*Corresponding author: <u>alain.quignard@ifpen.fr</u>, Tel.: +33 4 37 70 25 79

5 Abstract

Measurement of inorganics present in biomass fast pyrolysis liquids has been scarcely 6 investigated in the literature. In this work several analytical methods based on different 7 sample preparations were investigated and applied on a set of nine biomass fast pyrolysis 8 9 liquids covering a wide range of inorganics contents that have been measured using an ICP-10 OES (Inductively Coupled Plasma-Optical Emission Spectrometer) analyser. Several required mineralisation first steps were studied to completely dissolve the samples. Our 11 12 results show that the ISO 16967 method, initially developed for solid biomasses and adapted 13 here for bio-oils, was the most interesting one to quantify three major inorganics (i.e. potassium, magnesium and sodium), measurement of calcium contents remaining a 14 challenge when applied to bio-oils while it provides good results for reference materials. 15

16 Keywords

17 Analysis, ICP, Inorganics, Pyrolysis, Bio-oil, Lignocellulosic biomass, Metals

18 **1. Introduction**

Transformation of lignocellulosic biomass (wood, forest residues, straw,...) through 19 thermo-chemical processes is currently one of the main promising pathways to 20 produce biofuels and chemical intermediates, in substitution to fossil fuels and 21 products. Fast pyrolysis is one of these thermochemical routes that enable biomass 22 direct liquefaction, breaking down the lignocellulosic matrix and converting the 23 heterogeneous solid into fast pyrolysis bio-oils (FPBO). These liquids are known to 24 be complex chemical mixtures composed of oxygen organics (*i.e.* sugar monomers 25 and oligomers, carboxylic acids, aldehydes, ketones, esters, alcohols and phenolics), 26 27 water and inorganics present in the forms of free ions or solid particles. Variety of both fast pyrolysis processes and lignocellulosic biomass types contributes to the 28 large diversity of physical and chemical properties of the resulting bio-oils. Features 29 30 that are specific for each bio-oil should be taken into account to define which might be the most relevant way of valorisation. Considering biomass fast pyrolysis liquids 31 as full or partial substitutes of fossil heavy fuels or natural gas in industrial boilers [1-32 8] or as high-grade fuels for car engines after a suitable upgrading was one of the 33 main applications which attracted attention some decades ago. Many upgrading 34 35 approaches have been investigated, implying thermochemical treatments (e.g. hydrocracking and hydrodeoxygenation), physicochemical treatments (e.g. ultrasonic 36 cavitation, plasma, electrochemical) or chemical and biological treatments (e.g. 37 esterification and transesterification). In their review, Hansel et al. [9] discussed the 38 key points of these upgrading strategies, concluding that electrochemical treatment, 39 based on the retention of hydrogen from bio-oil water content during deoxygenation, 40 could be a relevant alternative to thermo-chemical processes which are effective but 41

42 disadvantaged by their low process cost competitiveness due to high temperature and high43 pressure conditions.

More recently, other applications have also gained interest, especially those head towards 44 valuable products coming from renewable resources, as enhanced by the present context of 45 green chemistry. Bio-oils could be considered as sources of a large range of products such 46 47 as hydrogen by steam reforming of bio-oils, biochemicals and commodities (olefins or BTX aromatics) achieved by a selective separation and/or after a hydrodeoxygenation step [10], 48 binders for electrodes or asphalt production in relation to the high content of phenolics in bio-49 oils, functional carbonaceous materials or even plastics [11]. However bio-oils exhibit several 50 51 undesirable features like a high acidity, a low thermal stability, a low heating value and a high viscosity that imply specific adaptations of current systems and/or additional prior upgrading 52 53 steps. To go further, more fundamental and techno-economic studies are generally required to optimize separation and reaction pathways sections in order to respect fuels or products 54 55 specifications and to rise from the early stages of technology development to commercial production scale with competitive costs when compared to current industrial processes 56 especially for those based on transformation of fossil resources. 57

Fast pyrolysis of biomass is well known for more than 35 years but only recently reached industrial maturity, with a few industrial size plants. These pre-commercial and commercial size units for burner fuel application and for co-processing to refinery for advanced biofuels are currently located in North America and North Europe, with almost ten operational (or to be started soon) semi and fully commercial scale units (Table 1). Table 1 intends to gather the information recovered from publications, presentations, web-sites and press releases [12].

65

Table 1. Pre-commercial and commercial biomass fast pyrolysis units

Unit Location	Technology	In Capacity Operation		In Operation		Fuel use
		since	Biomass (TPD)	Biomass (kt/y)	FPBO (kt/y)	

Fortum Joensuu Finland (1)		2014	240		50	District urban heating from forest
		Commercial				residue: needs of 10,000+ households.
Empyro/BTG_BTL (2) The Netherlands	VTT Fluid Bed	2015 Pre- commercial In production Namely capacity reached in 2017	120 (Wood residues)	35	24	12 years contract with Friesland- Campina (dairy producer) for FPBO co-combusted with natural gas for MP steam production and AKZO Nobel for sale of excess steam. The Empyro Plant became part of Twence on Jan1 st , 2019 for FPBO commercial production and use.
BTG-BTL/TechnipFMC (2) Finland from wood sawdust	BTG Rotating Cone	April 2019 Commercial	4*120?			April 2, 2019 'In the Netherlands, Finland will invest EUR100 million for 4 scheduled facilities' that makes it possible to produce oil from various waste materials including wood waste with aEUR25 million investment for a 1 st facility.
BTG-BTL/TechnipFMC with Setra		October 2010	120	35-40		Plan to build a production facility
(wood industry) a circompany Proom (2), Swoodon Bio-oil production scheduled to be started in 2021 from wood sawdust		4 ^{et} Commercial				be processed in rofinery for advanced biofuels.
BTG-BTL & Goofuels, (3), The Netherlands Bio-oil for marine application from sawdust and roadside grass cuttings	BTG Rotating Cone	November 2019 Pilot pant			1	'Pilot refinery for converting pyrolysis oil into 100% sustainable marine biodiesel for ships, to demonstrate that continuous production is feasible'.
BTG Bioliquids: Green Fuel Nordic Oy (GFN) Lieksa, Finland (4,5,6)	BTG Rotating Cone	December 2020 Commercial	120		24	GFN is a Green Fuel Nordic subsidiary operating the plant in the Kevätniemi industrial area in Lieksa.
BTG Bioliquids: Pyrocell Setra, Gävle, Sweden (4,5,6)	BTG Rotating Cone	Under construction, start-up in September 2021, Commercial	120 from sawdust	35-40	25	1 st announce in october 2019. Pyrocell is a Swedsih J.V. between the wood industry Setra & Preem.Production unit built next to the Kastet sawmill of Setra in GÂvle. FPBO to be co- processed in Preem refinery to produce advanced biofuels with 80 90% GHG reduction
RTP® (7,8) Renfrew Ontario-Canada	Ensyn CFB	2007 Pre- commercial	70		14	Memorial Hospital-New Hampshire (300,000 gal/y) since April 2014, Valley Regional Hospital Claremont (250,000 gal/y) since April 2015, Youngstown (Ohio) Thermal steam plant that powers district heating.
RTP® (7,8) Port Cartier, Quebec, Côte Nord, Ensyn, Arbec's sawmill and Groupe Rémabec	Ensyn - Envergent CFB	Completed 1 st Commercial Scale RTP®	200	65	46	FPBO for heating and for export to US: FPBO used for heating, and refinery Co-processing applications.
RTP® Aracruz Project (7,8) with Ensyn & Suzano from eucalyptus residues colocated to Suzano's 2.3 million t/yr pulp facility;	Ensyn – Envergent CFB	Basic engineering completed Commercial			95 (22 million gal/y)	FPBO for heating and for export to US and refining application.
(7,8) viena Project, Georgia (7,8) with Ensyn, Renova & Roseburg Forest Products from mill residues forest residues	Ensyn CFB	Project Commercial			86 (20 million gal/y)	rPBO to refineries for co- processing and/or heating & cooling clients.

(1) added to the existing fluidized bed boiler of the existing power Combined Heat and Power Plant

(1) added to the substraint interview of the

Virtual conference on "Co-Processing as route to deployment of advanced biofuels production" organised by the EU H2020 projects 4Refinery, Waste2Road, HyFlexFuel and the national Centre Bio4Fuels: https://www.etipbioenergy.eu/co-processing-as-route-to-deployment-of-advanced-biofuels-production-14-april-2021

(6) BIOFIT Industry Forum on Bioenergy Retrofitting of Refineries, 17 June 2021: https://www.biofit-h2020.eu/news-and-

- events/biofit-industry-forum-on-bioenergy-retrofitting-of-refineries-17-june-2021/
- (7) Ensyn / Honeywell's Envergent RTP® Process

(8) <u>http://www.ensyn.com/additional-expansion.htm</u>

66 Even if FPBO can be a first intermediate liquid to produce biofuels, their processing and refining to drop-in biofuels is not yet fully demonstrated and remains at pilot scale level or at 67 an early pre-commercial step (refer to BTG Bioliguids: Pyrocell Setra, Gävle, Sweden in 68 Table 1 or to Equinor Kalundborg refinery test on the Distillate Hydroteater) for 69 hydroprocessing. Regarding co-processing of FPBO, up to 5% by volume, a few trials have 70 71 been successfully performed on industrial Fluid Catalytic Cracking (FCC) units: Petrobras, Equinor Monstad refinery, Ensyn-UOP, BTG, using a injection line of the FPBO. 5% to 10% 72 73 FPBO, co-processing has a very limited impact on the FCC product yields: gasoline 74 production yield does not significantly change, as well as coke formation, when dry gas, Light 75 Cycle Oil (LCO), the FCC atmospheric gasoil fraction, liquid FCC bottoms yields slightly 76 decreased. Oxygen from FPBO is converted to CO, CO₂ and water with a significant 77 production: 3 to 6% respectively with 5% and 10% FPBO co-processing. [13-16]. FCC co-78 processing looks more mature than hydroprocessing.

79 Recently the International Maritime Organization (IMO) revealed its decarbonisation targets: 80 'IMO has adopted mandatory measures to reduce emissions of greenhouse gases from international shipping, under IMO's pollution prevention treaty (MARPOL) - the Energy 81 82 Efficiency Design Index (EEDI) mandatory for new ships, and the Ship Energy Efficiency Management Plan (SEEMP)' [17]. 2023-2030 mid-term measures aim to reduce carbon 83 intensity (CI) of the fleet by 40% (30% reduction of the CI in 2025 and up to 50% for several 84 ships including container ships) while long term 2030-2050 program seeks to reduce CI by 85 70%, with at least 50% of total annual reduction of GHG by 2050 (requiring about 85% less 86 CO₂ emitted per ship). 87

Today the main demonstrated application remains to replace fossil fuels in industrial size boilers [5-8, 18]. Near future applications could also concern home size boilers and Internal Combustion Engines such as adapted medium/low speed stationary diesel engines or turbines for electricity and steam production [18].

Properties and behaviour of FPBO are completely different from mineral oils [19-21]. In order to meet the national legislation requirements, to guarantee a suitable quality for FPBO used in industrial size boilers in existing installations, to enable FPBO trading, as well as to make possible the use of FPBO to produce green electricity by using stationary Internal Combustion Engines or turbines, FPBO standardization is mandatory.

A first standard of FPBO, to be used in industrial boilers, was performed by the ASTM 97 98 International Committee D02 which established a method (ASTM D7544) defining two fuel oil 99 grades with two different solid and ash contents [22]. Since the legislation and emission limits 100 differ from Europe to North America, European standards were also needed. In 2013 CEN received the mandate (M/525) from the European Commission to develop standards for 101 FPBO. A Working Group (WG41) was established under CEN/TC 19 (Gaseous and liquid 102 fuels, lubricants and related products of petroleum, synthetic and biological origin) in early 103 2014 to propose a standard for FPBO replacing light and heavy industrial boiler fuel oils, as 104 well as a Technical Specification (TS) for the quality for FPBO replacing fuel oils in stationary 105 106 ICE.

107 The deliverable from the WG 41 was the publication of the European Standard for FPBO use in boilers with > 10 MW EN 16900 [23] with an Inter-Laboratory Study (ILS) launched end of 108 109 2015. The ILS gathered 17 laboratories (Europe and North America) and 8 FPBO samples 110 prepared from 9 representative FPBO produced from pilot plants and commercial units, 111 covering a very large range of properties and origins (Table 2). The results of the ILS were incorporated in Annex C of the EN 16900 standard [23]. This ILS was the first of its kind 112 covering such a wide range of FPBO and such a number of analytical methods. The ILS 113 study revealed that some of the analytical methods derived from fossil fuels and used for 114 115 FPBO were not well adapted with a poor precision, especially for elementary analyses and metals. Moreover only one of the 17 laboratories measured the metals contents (sodium, 116 potassium, calcium and magnesium). The WG 41 also issued a Technical Report for the 117 quality for FPBO replacing fuel oils in stationary ICE, because there were too few data from 118 public experimental works, a lack of feedback on usage from the manufacturers and a 119

significant lack of adapted analytical methods to propose a Technical Specification 120 (document similar to a pre-standard for indication but without a standard status). Once again 121 the measurement of metals was a main concern, as well as the maximum allowed level 122 suitable to the existing adapted ICE technologies. Inorganics are well-known to be 123 detrimental compounds responsible for several problems when using FPBO (fouling or 124 corrosion in turbine systems, poisoning of reform catalysts, enhancement of coke formation 125 126 during catalytic upgrading,...), giving importance to the accurate measurement of the 127 inorganics contents in bio-oils.

128

Table 2. EN 16900 ILS FPBO typical range of physical and chemical properties

Property	Unit	Range
Density	kg/m ³	1185 - 1248
Viscosity at 40°C	mm²/s	10.7 - 1172
Water	wt%	14 - 31
Solid	wt%	0.03 - 6.8
Flash Point	°C	<40 - 58
Pour Point	°C	(-39) - (-9)
Carbon content	wt%	38 - 46
Hydrogen content	wt%	7.5 - 8.0
Nitrogen content	wt%	0.1 - 0.8
Sulfur content	wt%	0.005 – 0.46
Sodium content	mg/kg	<2 - 5
Potassium content	mg/kg	<20 - 250
Calcium content	mg/kg	<20 - 450
Magnesium content	mg/kg	<10 - 70

A significant number of works has already been published on the behaviour of inorganics during fast pyrolysis of lignocellulosic biomass and how these inorganics are distributed in the bio-oils and their ashes. However there are still very scarce literature studies related to analytical measurements of inorganics in chemically complex fast pyrolysis liquids.

Inorganics are usually quantified by a two-steps approach implying a first mineralisation step 133 aimed to completely dissolve liquid or solid samples (*i.e.* bio-oils or their ashes), followed by 134 135 a measurement of the aqueous resulting solutions by ICP-OES (Inductively Coupled Plasma-Optical Emission Spectrometer) technique. Mineralisation conditions are the main key 136 parameters of this analytical methodology, based on digestion of the sample using specific 137 acids: for instance literature works reported the use of nitric and/or hypochlorous acids [24, 138 139 25], mixtures of hydrofluoric and hypochlorous acids [26], hydrogen peroxide, nitric and hypochlorous acids [27] or hydrogen peroxide and nitric acid [28]. Mineralisation conditions 140 deeply depended on the laboratories and needed to be uniformed. Some years ago, a 141 standard method ISO 16967 has been published for the determination of major elements (*i.e.* 142 aluminium, calcium, iron, magnesium, phosphorus, potassium, silicon, sodium and titanium) 143 in solid biofuels. As far as we know, this method has already been applied to biomass fast 144 pyrolysis ashes, but not to bio-oils themselves. 145

From a larger viewpoint, inorganics analysis has been a topical issue since a long time 146 147 considering other matrices like water [29], petroleum products [30] or even more recently biodiesel and bioethanol [31]. As already mentioned, the approaches for organic matrices 148 use three types of protocols. The first one allows the direct introduction of the organic 149 150 substances (if those are liquid or soluble in a suitable solvent at room temperature) within the 151 plasma of an ICP-OES. The second one is based on the mineralization of the organics in 152 order to collect an aqueous fraction also analysed by ICP-OES. The last one is based on a 153 production of ashes from the material, that are also mineralized to be analysed by ICP-OES. Anyhow, such feedback for the analysis of FPBO is not existing and various assays have 154 155 been done in the past without real success for the analysis of inorganic contaminants in 156 FPBO.

157 In this work several analytical methods based on different sample preparations were 158 investigated and applied on a set of ten biomass fast pyrolysis liquids to measure the 159 inorganics contents using an ICP-OES analyser. Results will be compared in this

160 experimental study to define the most relevant analytical approach to determine the major161 inorganics present in bio-oils.

162 **2. Material and methods**

163 2.1. Samples

Nine samples produced from three different fast pyrolysis processes as well as from different types of lignocellulosic biomasses, were investigated in this study (Table 3). Sample A was produced from a Circulating Fluidised Bed fast pyrolysis demonstration plant of a hardwood feedstock. Samples B, C, D and E resulted from fast pyrolysis (feedstock origins are unknown). Samples F and G were produced from fast pyrolysis of wood and grass feedstock respectively. Samples H and I were obtained after solids removal by filtration of samples F and G respectively.

Table 3. Physical and chemical properties of the investigated bio-oils (results expressed ona wet basis)

Broporty	Unit	Samples								
Property	Unit	Α	В	С	D	Е	F	G	Н	I
Density at 15°C	g/cm ³	1.2361	1.2352	1.2300	1.2068	1.2073	1.1978	1.1895	1.1949	1.1976
Conradson carbon content	wt%	24.6	22.5	21.2	17.5	18.5	18.5	21.8	17.6	21.7
Carbon content	wt%	46.6	40.5	40.7	35.2	35.3	43.3	42.1	43.6	40.3
Hydrogen content	wt%	7.14	7.55	7.72	7.97	7.98	7.60	7.83	7.72	7.77
Oxygen content	wt%	45.06	51.36	51.34	55.61	55.80	47.96	48.33	48.06	49.79
Nitrogen content	wt%	0.277	0.1085	0.1315	0.183	0.1865	0.123	1.109	0.125	1.140

173 2.2. Chemicals

174	Aqueous multi-elemental standards were obtained from a stock solution (Spex Multiprep,
175	Stanmore, UK). All the aqueous solutions were prepared using ultrapure water (>18.2M Ω)
176	produced from a Millipore IQ 7003 water-purification system (Millipore, Molsheim, France).

Nitric acid (HNO₃, Suprapur) and methanol (MeOH, Normapur) used for the organic dilution
and calibration of the instrument were purchased from VWR Chemicals (Fontenay sous Bois,

France). hydrofluoric acid acid (HF, Suprapur) and hydrogen peroxide (H₂O₂, Suprapur) were
obtained from Merck (Darmstadt, Germany).

181 Reference materials (bush branches and leaves, NCS DC 73349 and wood fuels NJV945)
182 were purchased from LGC (Molsheim, France) and Analytical Standard (Molnlycke,
183 Sweeden) respectively.

184 2.3. Sample preparation

185 The following protocols of sample preparation were performed prior to ICP-OES analyses.

ISO 16967 Method. The protocol was adapted from the standard method ISO 16967 'Solid 186 biofuels - Determination of major elements - Al, Ca, Fe, Mg, P, K, Si, Na and Ti' originally 187 dedicated to the analysis of solid biomass samples. In our work the solid biofuels were 188 189 replaced by bio-oils and the determination of aluminium, calcium, iron, magnesium, phosphorus, potassium, silicon and sodium contents was obtained after a digestion of the 190 samples using hydrogen peroxide, nitric acid and hydrofluoric acid reactants under pressure 191 and temperature in a closed vessel. Based on a two-stages protocol occuring at 190°C and 192 193 150°C, this method used an oxidative acid mixtures combined to hydrofluoric acid. Such mixture has the ability to digest most of the major and minor contaminants of a bioproduct. 194 195 The excess of hydrofluoric acid was neutralised and the remaining solution was analysed using ICP-OES (Appendix 1). Data obtained with reference or 'spiked' materials are 196 197 available in Appendix 2.

Protocol based on the method developed by Wondimu et al. Based on a method described by Wondimu et al [32], a protocol designed in this work as 'Wondimu protocol' was performed to mineralize 0,1 g of a bio-oil prior to the analysis by ICP-OES of the resulting aqueous solution. This sample preparation involved the use of a hydrogen peroxide and nitric acid mixture (10 mL) as well as a microwave Teflon bomb operating at 800 W under a temperature gradient (maximum at 230°C). This mixture of acid was also oxidative and very attractive to digest carbonaceous material, but the absence of hydrofluoric acid would

hamper the digestion of some refractory oxides present in the material. Temperatures up to
230°C were applied, involving several different temperature ramps and residence times as
described in Appendix 1.

208 Protocol by methanol dilution. This third approach used in this work was based on a method proposed by WG41 for the analysis of pyrolysis oils. It consisted of diluting a bio-oil 209 210 before filtration with a paper filter to eliminate undissolved materials and of a direct introduction into the ICP-OES device. The protocol was modified from method EN 16476 211 where the sample is dissolved in kerosene and the viscosity change was corrected by the 212 213 use of an internal standardization. Since FPBO are not soluble in hydrocarbons, kerosene 214 was replaced by methanol and the 2 times dilution was also adapted and reduced to 20 times dilution in the solvent to minimize the viscosity difference that would not be corrected 215 216 by the use of the internal standard.

217 Protocols for ashes production and their mineralisation. Ashes were first produced by calcination of a bio-oil (sample A) using a Carbolite furnace and a Eurothem control system. 218 For each experiment, 3 g of bio-oil were placed in a platinum crucible heated from room 219 temperature to 775°C with a heat temperature program adapted to prevent any foam 220 221 phenomenon. Once the final temperature was reached, the furnace temperature was maintained at 775°C during 3 hours before cooling. Based on reproducibility implying 21 222 calcinations, the ashes content of sample A was determined to be 0.26 %wt + 0.01 %wt (on 223 wet basis). In order to supply enough matter for ICP and WXRF analyses (*i.e.* 0,3 g), 40 224 225 calcination experiments were performed on sample A. In a second time, a mineralisation step was carried out on ashes (0.1 g) prior to ICP-OES analysis: 0.1 g of ashes were introduced 226 in a microwave bomb Teflon operating at 800 W under a temperature gradient up to 180°C in 227 presence of 8 mL of nitric acid. Then 2 mL of hydrofluoric acid were added in the bomb and 228 229 the mixture was heated at 220°C during 15 min at 800 W. The resulting solution was submitted to an evaporation step to remove hydrofluoric acid ; 1 mL of nitric acid and some 230 231 water (q.s. 25 mL) were finally added.

232 2.4. Apparatus and analytical conditions

The ICP-OES instrument was a Spectro Arcos device equipped with different nebulizers 233 234 depending on the type of solution to be analysed. For conventional nitric acid solution, the instrument was equipped with a modified Lichte nebulizer mounted on a cyclonic chamber 235 and the plasma was monitored under aqueous conditions (refer to Table 4). For solution still 236 containing hydrofluoric acid, the instrument was equipped with a Burgener Miramist nebulizer 237 238 and the nebulization chamber was a cyclonic chamber made of Teflon, but the aqueous conditions of the plasma were kept constant. For organic solutions, the ICP Arcos was 239 equipped with a cooled (-10°C) cyclonic chamber and a Burgener T2002 nebulizer. The ICP-240 OES was tuned in order to sustain organic introduction (refer to Table 4). The calibration 241 curves mostly covered 0 to 100 mg/L with 11 standards, including 5 standards between 0 to 242 243 1 mg/L.



Table 4. Plasma and nebulization conditions for the ICP-OES analysis

Parameter	Unit	Conditions for analysis of aqueous samples	Conditions for analysis of organic samples
Plasma power	W	1350	1650
Carrier gas flow	L/min	0.95	0.60
Auxiliary gas flow rate	L/min	0.80	2.00
Plasma gas flow	L/min	12	16
Pump speed	rpm	30	15
Rinse time with samples	s	300	200
Injector diameter	mm	1.8 (2.5 for hydrofluoric acid analysis)	1.2

The WDXRF device used for the semi-quantitative determination of the composition of the ashes (~70 elements determined) was a Thermo Perform'X apparatus (4,2 kW) using Uniquant 5.0 incorporated to OXAS V2 Software. The broad spectrum was acquired by a peak-hoping procedure proposed by the instrument and the intensity for each line was compared to sensitivity coefficient already integrated in the Uniquant Software.

3. Results and discussion

3.1. Inorganics measurement by mineralisation and ICP-OES analyses

Major inorganics contents in a FPBO (sample A) were measured using several protocols, all based on a mineralisation first step and a ICP-OES analysis second step. On one hand, measurements were performed on the bio-oil using the ISO 16967 method or Wondimu protocol, while, on the other hand, measurements were carried on the ashes resulting for calcination of sample A. For all type of measurements, the analysis was duplicated to verify the repeatability of the procedure. Ashes were also directly analysed by a semi-quantitative WXRF method to compare data with the one got by mineralisation and ICP-OES analysis.

Inorganics contents measured using the method ISO 16967 or Wondimu protocol directly 259 applied on the bio-oil are reported in Table 5. When both results issuing from the duplicate 260 261 analysis were within the 10% difference, only one result was reported. If this difference was higher than 10%, both results are reported. Furthermore contents of inorganics in bio-oil 262 263 were calculated taking into account the ashes content of sample A (i.e. 0,26 %wt) and the contents measured directly on the ashes; these calculated contents are also presented in 264 265 Table 5. According to these data, iron was the most abundant inorganic element quantified in the bio-oil A. Its unexpected high level (952 mg/kg determined by the method ISO 16967) in 266 comparison with literature data [5] indicates that the bio-oil may have been probably 267 contaminated with iron oxide under inappropriate storage conditions [33]. Other major 268 269 elements in this sample were potassium, phosphorus and calcium with contents ranging from 100 to 200 mg/kg. Mainly concentrated in ashes, silicon certainly came from sand particles 270 used in the fluidised bed reactor for wood fast pyrolysis [4]. In addition, lower contents of 271 272 aluminium, sodium, magnesium and platinum, each inferior to 20 mg/kg, were measured 273 from the bio-oil.

As regards the comparison of the analytical methods used in this work, results about iron and potassium contents are in good agreement, whether they were obtained by using the ISO 16967 method or Wondimu protocol. These elements were mainly concentrated in ashes whose analyses by ICP-OES and WRXF were both consistent. Concerning silicon, the content measured by applying the Wondimu protocol on bio-oil is much inferior to the one

determined using the ISO 16967 method or the ones calculated from ICP or WRFX analyses of ashes. This underestimation of Wondimu protocol is explained by the fact that the nitric acid and hydrogen peroxide mixture used was not suitable to get a good solubilisation of silica during the mineralisation step, on the contrary to the method ISO 16967 which required the use of hydrofluoric acid.

Table 5 shows that quantifications of calcium, phosphorus and sulphur in the investigated FPBO (sample A) using different approaches were not successful. This is an unexpected result for calcium and phosphorus as their quantification was not an issue when using reference materials like bush and branches or wood fuel material (refer to Appendix 2).

288 This reveals that the difference is probably not due to loss of phosphorous by volatility or loss of calcium by incomplete dissolution, as these elements were validated with reference 289 290 materials. For phosphorous, the value around 130 mg/kg is consistent for both ISO 16967 291 and Wondimu protocols performed directly on the bio-oil. Nevertheless the two values obtained with the ISO 16967 protocol reveal that phosphorous might be associated to 292 sludges that are not homogeneous in the sample. One of the limitation of the digestion by 293 294 micro-wave in closed vessel is the limited mass of sample (100 mg) that is used in the 295 experiment. Perfect homogeneity with such low mass of sample is difficult to reach and this is why two replicates are systematically carried out in order to reveal such heterogeneity. 296 However phosphorus contents measured on the ashes by ICP and WRXF were both in a 297 good agreement and were clearly lower than the ones resulting from the direct analysis of 298 299 the bio-oil, which tends to confirm the assumption of loss of phosphorus during calcination experiments to produce the ashes. Analyses of ashes showed that phosphorus was probably 300 not initially present as phosphates in bio-oils and that phosphorus may be more likely 301 integrated as a part of organic molecules, maybe as particles forms, being consistent with 302 303 the fact that phosphorus could be largely retained in (lignin-rich) char after fast pyrolysis [34]. The case of calcium is a little bit more difficult to cope with. Values are varying widely 304 between 59 to 238 mg/kg in the investigated FPBO (sample A) using several analytical 305

procedures. Once again, the ISO 16967 protocol was validated for calcium using the reference materials (refer to Appendix 2). It is interesting to see that the two values measured on ashes materials are consistent and that, in the case of protocols using a small mass of sample (ISO 16967 and Wondimu protocols), the results reveal potential heterogeneity with significantly different values coming from replicates. However mean contents for both protocols (147 mg/kg for ISO 16967 and 166 mg/kg for Wondimu) even if a little bit higher, are consistent with the mean value obtained with ashes.

Like phosphorus, sulphur is known to be difficult to be analysed by ICP technique following a 313 mineralisation step in the case of fossil fuels. Sulphur was quantified at 117 mg/kg in the bio-314 315 oil with the Wondimu protocol while its content was much more lower in the ashes (35-46 mg/kg). This element might have been lost during calcination experiments carried out at 316 317 775°C to produce ashes from the bio-oil whereas losses might have been less important or not possible when closed system are used. This is the case of the micro-wave digestion in 318 319 closed vessel at moderate temperatures such as the ones employed during the method ISO 320 16967 and Wondimu protocol.

According to results obtained with the method ISO 16967, other elements (*i.e.* aluminium, sodium, magnesium and platinum) were also quantified in the sample A with contents inferior to 25 mg/kg. Except for aluminium whose quantification by Wondimu protocol suffered from a lack of repeatability, overall data coming from the analysis of the bio-oil or the ashes were globally consistent, being within the same order of magnitude. Nevertheless one should keep in mind that sodium quantification is usually a challenging task, due to frequent contamination from the glassware used for sample preparation prior to analysis [33].

Table 5. Contents of major inorganics in a bio-oil (sample A) determined according several
 analytical methods (mean values are reported except for significantly different results)

	Contents me the bio-oil and	asured from alysis [mg/kg]	Contents calculated from the ashes analysis [mg/kg]		
Element	ISO 16967 protocol	Wondimu protocol	ICP-OES	WXRF	

Fe	952.0 ± 95.2	812.0 ± 81.2	734.0	682.0
Si	271.0 ± 27.1	45.3 ± 4.5	292.0	291.0
к	159.0 ± 15.9	176.0 ± 17.6	136.0	134.0
Са	59.0 ; 235.0	238.0 ; 94.3	97.3	109.0
Р	10.3 ; 132.2	160.0 ± 16.0	2.9 ; 2.3	5.0
S	not measured	117.0 ± 11.7	46.3 ; 40.2	35.0
AI	22.3 ; 19.8	37.6 ; 78.6	15.2	12.0
Na	13.5 ; 17.6	13.8 ± 1.4	10.2	7.0
Mg	16.0 ± 0.2	<25.0	14.0	12.0
Pt	not measured	<12.5	1.6	15.0

330 **3.2.** Comparison of method ISO 16967 and method by simple dilution and ICP-OES

331 analysis

In the previous part, the ISO 16967 method proved to be relevant for measuring major inorganics contents in a FPBO. This method was then applied to the analysis of eight other bio-oils coming from different fast pyrolysis conditions and different lignocellulosic biomasses (samples B to I). On the same time, these bio-oils were also analysed by ICP-OES after being simply diluted by 20 times in methanol and filtrated ; as yet explained, this approach had been proposed during a previous inter-laboratory study organised by the working group WG41 from CEN/TC 19 committee.

Reported in Figures 1 to 4, contents of the four main alkali inorganics (i.e. potassium, 339 340 calcium, magnesium, sodium) of samples B to I varied over a large range of values, depending on the element and on the bio-oil. Contents measured using the method ISO 341 342 16967 were systematically significantly higher than the ones obtained by methanol dilution 343 and ICP-OES analysis, except for a few cases (*i.e.* potassium for samples B and D, calcium for samples D, F and G, sodium for sample F). The drawback of analytical method based on 344 345 simple dilution is that it tends to under-estimate alkali contents and, because of a partial 346 solubilisation of the oil in methanol during sample preparation, it does not allow to take into consideration inorganics that were not methanol-soluble and that were retained during 347 348 filtration priori to injection in the ICP-OES analyser. Such results are consistent with previous VTT recommendations [12]. 349



Figure 1. Contents of calcium in bio-oils (samples B to I) measured by the method ISO 16967 (grey bars) and by the method based on simple dilution of the samples prior to ICP-

352

OES analysis (dotted bars).



Figure 2. Contents of potassium in bio-oils (samples B to I) measured by the method ISO
 16967 (grey bars) and by the method based on simple dilution of the samples prior to ICP OES analysis (dotted bars).



Figure 3. Contents of magnesium in bio-oils (samples B, C, D, E, G and I) measured by the

357 method ISO 16967 (grey bars) and by the method based on simple dilution of the samples

358

prior to ICP-OES analysis (dotted bars).



Figure 4. Contents of sodium in bio-oils (samples B to I) measured by the method ISO
 16967 (grey bars) and by the method based on simple dilution of the samples prior to ICP OES analysis (dotted bars).

4. Conclusion

Dealing with inorganics is one of the key issue for the industrial valorisation of biomass fast 363 pyrolysis oils (FPBO) as substitutes of petroleum products in the fields of energy or chemical 364 products. However characterization of inorganics in such liquids has been very scarcely 365 reported in literature and no analytical method has been yet universally adopted to measure 366 their contents. Experimental conditions are varying very largely depending on each 367 laboratory practices, without any real consensus on the subject from the scientific 368 community. This study was dedicated to the measurement of inorganics in bio-oils and their 369 ashes. Several methods were investigated, showing that the ISO 16967 method, initially 370 371 developed for solid biomasses, and adapted for bioliquids, was the most interesting one to quantify three major inorganics (i.e. potassium, magnesium and sodium) in FPBO, 372 measurement of calcium contents remaining a challenge when applied to bio-oils while it 373 provides good results for reference materials.. Further work is now required implying for 374 375 instance round robins based on this method to assess this analytical approach at a larger scale of samples, before it could be introduced as a standard analytical method. 376

377

5. Acknowledgements

The authors wish to thank Anissa AMASSAD and Sylvain CARBONNEAUX (IFP Energies nouvelles) for help concerning production of ashes from calcinations of a biomass fast pyrolysis oil. The authors also thank Eija ALAKANGAS (WG41 Convenor) and Anja OASMAA, both from VTT who actively participate to the CEN TC19/WG41 group as well as Ortwin COSTENOBLE from NEN Energy and Bert VAN DE BELD from BTG.

383

384 6. References

[1] Bridgwater A.V., Review of fast pyrolysis of biomass and product upgrading, Biomass and
Bioenergy (2011) (doi:10.1016/j.biombioe.2011.01.048).

[2] Carpenter D., Westover T., Howe D., Deutch S., Starace A., Emerson R., Hernandez S.,
Santosa D., Lukins C., Kutnyakov I., Catalytic hydroprocessing of fast pyrolysis oils: Impact
of biomass feedstock on process efficiency, Biomass and Bioenergy 96 (2017) 142-151
(http://dx.doi.org/10.1016/j.biombioe.2016.09.012).

[3] Dhyani V., Bhaskar T., A comprehensive review on the pyrolysis of lignocellulosic
biomass, Renewable Energy 129 (2018) 695-716
(http://dx.doi.org/10.1016/j.biombioe.2016.09.012).

[4] Czernik S., Bridgewater T., Overview of Applications of Biomass Fast Pyrolysis Oil,
Energy & Fuels 18 (2004) 590-598 (http://dx.oi.org/10.1021/ef034067u).

[5] Butler E., Devlina G., Meier D., Mc Donnell K., A review of recent laboratory research and
commercial developments in fast pyrolysis and upgrading, Renewable and Sustainable
Energy Reviews 15 (2011) 4171-4186 (doi:10.1016/j.rser.2011.07.035).

[6] Lehto J., Oasmaa A., Solantausta Y., Kytö M., Chiaramonti D., Fuel oil quality and
combustion of fast pyrolysis bio-oils, VTT Technology 87 (2013). (ISBN 978-951-38-7929-7
(Soft back ed.), 978-951-38-7930-3 (URL: http://www.vtt.fi/publications/index.jsp)
http://www.vtt.fi/inf/pdf/technology/2013/T87.pdf).

[7] Lehto J., Oasmaa A., Solantausta Y., Kytö M., Chiaramonti D., Review of fuel oil quality
and combustion of fast pyrolysis bio-oils from lignocellulosic biomass, Applied Energy 116
(2014) 178-190 (http://dx.doi.org/10.1016/j.apenergy.2013.11.040).

[8] Oasmaa A., Van De Beld B., Saari P., Elliott D.C., Solantausta Y., Norms, standards, and
legislation for fast pyrolysis bio-oils from lignocellulosic biomass: American Chemical Society.

408 Energy and Fuels 29 (2015) 2471-2484 (DOI: 10.1021/acs.energyfuels.5b00026).

[9] Valle B., Remiro A., García-Gómez N., Gayubo A., Bilbao J., Recent research progress
on bio-oil conversion into bio-fuels and raw chemicals: a review. Journal of Chemical
Technology and Biotechnology 94 (2019) 670–689 (https://DOI 10.1002/jctb.5758).

[10] S. Hansen, A. Mirkouei, L.A. Diaz, A comprehensive state-of-technology review for
upgrading bio-oil to renewable or blended hydrocarbon fuels, Renewable and Sustainable
Energy Reviews 118 (2020) 109548, https://doi.org/10.1016/j.rser.2019.109548

[11] Hu X., Gholizadeh M., Progress of the applications of bio-oil. Renewable and
Sustainable Energy Reviews 134 (2020) 110-124
(https://doi.org/10.1016/j.rser.2020.110124).

[12] IEA Bioenergy Task 39, 'Progress in Commercialization of Biojet /Sustainable Aviation
Fuels (SAF): Technologies, potential and challenges', May 2021 (ISBN# 978-1-910154-878).

[13] Virtual conference on "Co-Processing as route to deployment of advanced biofuels
production" organised by the EU H2020 projects 4Refinery, Waste2Road, HyFlexFuel,
Bio4Fuels, 14 April 2021 (<u>https://www.etipbioenergy.eu/co-processing-as-route-to-</u>
<u>deployment-of-advanced-biofuels-production-14-april-2021</u>).

[14] BIOFIT Industry Forum on Bioenergy Retrofitting of Refineries, 17 June 2021
(https://www.biofit-h2020.eu/news-and-events/biofit-industry-forum-on-bioenergy-retrofittingof-refineries-17-june-2021).

[15] 2nd Eu-India Conference on Advanced Biofuels, New Delhi, 11-13 March 2019,
Advanced Biofuels from Fast Pyrolysis Bio-Oil, K. Overwater,
(https://ec.europa.eu/info/sites/info/files/20_koos_overwater.pdf).

[16] 29th EUBCE 2021, 26-29 April 2021, Co-Processing Pyrolysis Oil Biocrude in an Fcc to
Produce Renewable Fuels, Dan Szeezil,
(http://programme.eubce.com/2021/abstract.php?idabs=18968&idses=1279&idtopic=32).

- 434 [17] International Maritime Organization, 'IMO action to reduce greenhouse gas emissions
 435 from international shipping',
 436 (https://sustainabledevelopment.un.org/content/documents/26620IMO_ACTION_TO_REDU
 437 CE GHG EMISSIONS FROM INTERNATIONAL SHIPPING.pdf).
- [18] Oasmaa A., Peacoke C., Gust S., Meier D., McLellan R., Norms and Standards for
 Pyrolysis Liquids. End-User Requirements and Specifications, Energy & Fuels 19 (2005)
- 440 2155-2163 (https://doi.org/10.1021/ef040094o).
- [19] Oasmaa A., Peacoke C., Properties and fuel use of biomass-derived fast pyrolysis
 liquid A guide, VTT Publication 731, 2010. (ISBN 978-951-38-7384-4.
 (http://www.vtt.fi/inf/pdf/publications/2010/P731.pdf).
- 444 [20] Mohan D., Pittman C. U., Steele Jr. P. H., Pyrolysis of Wood/Biomass for Bio-oil: A
 445 Critical Review, Energy & Fuels, 20 (2006) 848-889 (https://doi.org/10.1021/ef0502397).
- [21] Kan T., Strezov V., Evans T.J., Lignocellulosic biomass pyrolysis: A review of product
 properties and effects of pyrolysis parameters, Renewable and Sustainable Energy Reviews
 57 (2016) 1126-1140. (http://dx.doi.org/10.1016/j.rser.2015.12.185)
- [22] ASTM Committee D02 on Petroleum Products, Liquid Fuels, and Lubricants: ASTM D7544.
- 451 [23] European Standard EN 16900 Fast pyrolysis bio-oils for industrial boilers 452 Requirements and test methods.
- [24] Fahmi R., Bridgwater A.V., Donnison I., Yates N., Jones J.M., The effect of lignin and
 inorganic species in biomass on pyrolysis oil yields, quality and stability, Fuel 87 (2008)
 1230-1240 (http://dx.doi:10.1016/j.fuel.2007.07.026).
- [25] Elliott D., Meier D., Oasmaa A., vand de Beld B., Bridgwater A., Marklund M., Results of
 the International Energy Agency Round Robin on Fast Pyrolysis Bio-oil Production, Energy
 Fuels 31 (2017) 5111-5119 (https://doi.org/10.1021/acs.energyfuels.6b03502).
- 459 [26] Jendoubi N., Broust F., Commandre J.M., Mauviel G., Sardin M., Lédé J., Inorganics
- distribution in bio oils and char produced by biomass fast pyrolysis: The key role of aerosols,

- 461 Journal of Analytical and Applied Pyrolysis 92 (2011) 59-67 (http://dx. 462 doi:10.1016/j.jaap.2011.04.007).
- [27] Eom I.Y., Kim J.Y., Lee S.M., Cho T.S., Yeo H., Choi J.W., Comparison of pyrolytic
 products produced from inorganic-rich and demineralized rice straw (Oryza sativa L.) by
 fluidized bed pyrolyzer for future biorefinery approach, Bioresource Technology 128 (2013)
 664-672 (http://dx.doi.org/10.1016/j.biortech.2012.09.082).
- 467 [28] Wigley T., Yip A.C.K., Pang S., A detailed product analysis of bio-oil from fast pyrolysis
 468 of demineralised and torrefied biomass, Journal of Analytical and Applied Pyrolysis 123
 469 (2017) 194-203 (http://dx.doi.org/10.1016/j.jaap.2016.12.006).
- [29] U.S. EPA. 1994. Method 200.7: Determination of Metals and Trace Elements in Water
 and Wastes by Inductively Coupled Plasma-Atomic Emission Spectrometry, Revision 4.4.
 Cincinnati, OH.
- [30] Sánchez R., Todolí J.-L., Lienemann C.-P., Mermet J.-M., Determination of trace
 elements in petroleum products by inductively coupled plasma techniques: A critical review,
 Spectrochimica Acta Part B 88 (2013) 104-126 (http://dx.doi.org/10.1016/j.sab.2013.06.005)
- 476 [31] Sánchez R., Sanchez C., Lienemann C.-P., Todoli J.-L., Metal and metalloid
 477 determination in biodiesel and bioethanol, Journal of Analytical Atomic Spectrometry 30
 478 (2015) 64 (<u>https://doi.org/10.1039/C4JA00202D</u>).
- [32] Wondimu T., Goessler W., Irgolic K., Microwave digestion of "residual fuel oil" (NIST 479 SRM 1634b) for the determination of trace elements by inductively coupled plasma-mass 480 481 spectrometry, Fresenius Analytical Chemistry 367 (2000)35-42 Journal of 482 (https://doi.org/10.1007/s002160051595)
- [33] Diebold J.P., A review of the chemical and physical mechanisms of the storage stability
 of fast pyrolysis bio-oils, NREL/SR-570-27613, 2000.

- 485 [34] Leijenhorst E.J., Wolters W., van de Beld L., Prins W., Inorganic element transfer from
- 486 biomass to fast pyrolysis oil: Review and experiments, Fuel Processing Technology, 149
- 487 (2016) 96–111 (http://dx.doi.org/10.1016/j.fuproc.2016.03.026).